

LCOE reduction potential of parabolic trough and solar tower CSP technology until 2025

S. Dieckmann, J. Dersch, S. Giuliano, M. Puppe, E. Lüpfer, K. Hennecke, R. Pitz-Paal
(German Aerospace Center, DLR)

M. Taylor, P. Ralon
(International Renewable Energy Agency, IRENA)

SolarPACES Conference
Abu Dhabi
October 11-14, 2016



Knowledge for Tomorrow



Content


1. Introduction
2. System Overview 2015 vs. 2025
3. Cost Analysis
 1. Parabolic Trough Field
 2. Solar Tower System
 3. Thermal Energy Storage
 4. Power Block
4. Results
5. Conclusion



Source: noorouarzazate.com

1. Introduction – Contributing Cost Factors for LCOE

- Example based on annuity loan over 25 years at 7.5%
- Main Impact factors:
 - Investment cost (CAPEX)
 - Financing conditions
- **LCOE estimation is mainly CAPEX estimation**




1. Introduction – Methodology and Boundary Conditions

- Technology-based bottom-up approach relying on inhouse expertise as well as external data sources
- Contrasted with published Power Purchase Agreements (NOOR II + III)
- Ouarzazate, Morocco, DNI: 2017 / 2558 / 2935 kWh/(m²·a)
- Currency: US-\$₂₀₁₅
- CSP capacity growth to about 20GW in 2025


	Parabolic Trough	Solar Tower
Nominal Electric Net Output	160 MW	150 MW
Thermal Storage Capacity	7.5 h	9 h



2. System Overview – Parabolic Trough 2015 → 2025



2. System Overview – Solar Tower 2015 → 2025



3.1 Cost and Performance – Parabolic Trough Field

	2015	2025
Collector	UltimateTrough™	Future Trough
Turnkey Cost*	231 \$/m ²	177 \$/m ²

*: includes site preparation, collectors, piping, cabling, HTF, HTF system, assembly & construction

- Total cost reduction: 23%
- Cost reduction equally distributed over sub-components
- 25% less collectors, foundations, pylons, drives and receivers
- Collector structure: -14 \$/m²
 - (Sub-)supplier standards and standardized designs
 - Automatization in manufacturing
- HTF cost: -18\$/m²



Source: sbp.de



3.2 Cost and Performance – Solar Tower System

	2015	2025
Heliostat	Stellio™	Future Heliostat
Heliostat Field Cost*	143 \$/m ²	103 \$/m ²
Tower Cost	90,000 \$/m	72,000 \$/m
Receiver Cost	125 \$/kW _{th}	100 \$/kW _{th}

*: includes site preparation, heliostat field, cabling, assembly & construction

- Total heliostat cost reduction: -28%
- Mirrors: -9 \$/m²
 - Reach parabolic trough mirror cost
- Drives: -11 \$/m²
 - Replace costly slewing drives
 - Closed loop control
- Structure & foundations: - 10 \$/m²
 - Bigger market volume, standardized designs
 - Industrialized assembly procedures

- Total receiver cost reduction: -20%
 - Improved material concepts
 - Optimized absorber surface utilization
 - Higher average solar flux



Source: sbp.de



3.3 Cost and Performance – Thermal Storage

	Parabolic Trough		Solar Tower		
	2015	2025	2015	2025	
Cost	42	26	26	22	\$/kWh
Hot tank temperature	385	530	565	600	°C

- Both technologies:
 - Adapted storage materials
 - Innovative storage concepts (e.g. Single-tank thermocline storage)
- Tower Storage Costs: -4 \$/kWh (-17%)
- Trough Storage Costs: -16 \$/kWh (-38%)
 - -12.5 \$/kWh for storage medium
 - halved storage fluid mass thanks to higher temperature
 - -3 \$/kWh for HXs and pumps



Source: www.renewableenergyfocus.com



3.4 Cost and Performance – Power Block

	Parabolic Trough		Solar Tower		
	2015	2025	2015	2025	
Cost	1220	1100	1270	1100	\$/kW
Live Steam Temperature	383	520	555	590	°C
Thermal Efficiency	38.4	42.7	42.8	43.9	%

- Minor cost reduction potential
- Dry cooling predominant
- Efficiency gain thanks to increased live steam temperatures



Source: The Energy Blog – energy.org.za

3. Cost and Performance – Overview and Indirect Cost

Unit		2015		Cost variation [%]		2025	
		Trough	Tower	Trough	Tower	Trough	Tower
Direct EPC costs	Mio. \$	675	598	-24	-23	508	459
Engineering, management, add. EPC services	% on direct EPC	5				2	
Profit margin and contingencies	% on direct EPC	10				6	
Indirect EPC cost	Mio. \$	101	144	-60	-74	41	37
Project development	% on dir.+indir. EPC	10				4	
Land cost	\$ / m ² land	1				1	
Infrastructure	Mio. \$	6				6	
Additional owner's cost	% on dir.+indir. EPC	3				2	
Owner's cost	Mio. \$	112	113	-61	-60	44	46
CAPEX	Mio. \$	888	854	-33	-37	593	541
OPEX	% of CAPEX	2.2				2.1	




4. Results – Plant Output and LCOE

Parabolic Trough	2015	2025
Annual el. output	576 GWh	625 GWh
Overall efficiency	15.1%	17.0%

Solar Tower	2015	2025
Annual el. output	598 GWh	644 GWh
Overall efficiency	15.5%	18.3%

- Until 2025 LCOEs decrease to
 - 10 \$-ct/kWh for medium DNI levels
 - 7 \$-ct/kWh for high DNI levels and favourable financing conditions
- PPAs \approx LCOE + 1...1.5 \$-ct/kWh
- Assuming 4% WACC, LCOE values match well to published PPAs from NOOR



5. Conclusion

- CAPEX: 5600 → 3600 \$/kW (-35%) for both technologies (7.5/9h storage)
- LCOEs can reach 7 \$-ct/kWh (high DNI, favourable financing)
- Major cost drivers Trough:
 - Molten salt as HTF
 - Trough collector CAPEX
- Major cost drivers Tower
 - Steep learning curve, reduction of contingencies, overcoming of teething troubles
 - Heliostat field CAPEX
- Financing conditions are a massive cost driver:
 - For each 1%-point WACC reduction LCOEs decrease by 1.1 \$-ct/kWh
- ➔ IRENA publication (2016): „*The power to change – Solar and Wind Cost Reduction Potential to 2025*”



MANY THANKS

to all contributing
partners, co-authors
and colleagues!



THANK YOU

for your attention!

Contact:

Simon Dieckmann
DLR – Line Focus Systems

Simon.Dieckmann@dlr.de



Knowledge for Tomorrow

