

# Carbon neutral archipelago – 100% renewable energy supply for the Canary Islands

Hans Christian Gils<sup>a</sup>, Sonja Simon<sup>a</sup>

<sup>a</sup> DLR – German Aerospace Center, Pfaffenwaldring 38-40, 70569 Stuttgart, Germany

**Keywords:** Energy Scenario, Renewable Energy, Canary Islands, Hydrogen, Demand Response, Energy System Modelling

## Highlights:

- A pathway to a 100% renewable energy supply for the Canary Islands is presented
- Hourly system operation is analysed, considering flexibility options and sector linkage
- Results show feasibility of a carbon neutral energy supply with local resources
- High resolution power system model highlights importance of grid connections

## Abstract:

As many other small islands and archipelagos, the Canary Islands depend to a high degree on energy imports. Despite its small surface, the archipelago has a high potential for renewable energy (RE) technologies. In this paper, we present a scenario pathway to a 100% RE supply in the Canary Islands by 2050. It relies on a back-casting approach linking the bottom-up accounting framework Mesap-PlaNet and the high resolution power system model REMix. Our analysis shows that locally available technology potentials are sufficient for a fully renewable supply of the islands' power, heat, and land transport energy demands. To follow the pathway for achieving a carbon neutral supply, expansion of RE technology deployment needs to be accelerated in the short-term and efforts towards greater energy efficiency must be increased. According to our results, an extended linkage between energy sectors through electric vehicles as well as electric heating, and the usage of synthetic hydrogen can contribute notably to the integration of intermittent RE power generation. Furthermore, our results highlight the importance of power transmission in RE supply systems. Supply costs are found 15% lower in a scenario considering sea cable connections between all islands.

## Abbreviations:

BAU – Business-As-Usual, BEV – Battery Electric Vehicle, CCGT – Combined Cycle Gas Turbine, CHP – Combined Heat and Power, CSP – Concentrating Solar Power, DC – Direct Current, DR – Demand Response, GDP – Gross Domestic Product, GHG – Greenhouse Gases, PSH – Pumped Storage Hydro, PV – Photovoltaic, RE – Renewable Energy, TES – Thermal Energy Storage

# 1 Introduction

1 The need to mitigate anthropogenic global CO<sub>2</sub>-emissions increasingly focuses on the current energy  
2 system, which produced 78% of global greenhouse gas (GHG) emissions between 1970 and 2010 [1].  
3 Policy already addresses the transformation of the existing system towards a more sustainable  
4 energy supply on a large scale [2] and local action plans aim at an increased use of renewable  
5 energies. The integration and balancing of large fluctuating renewable energy supply with the future  
6 demand represents major challenges for national and continental energy systems. For Island systems  
7 these challenges are even more pronounced. Owing to their remote situation, islands are often  
8 dependent on fossil fuel imports, which are typically expensive due to transport costs [3, 4].  
9 Remoteness and size lead to small isolated markets, with few actors and a low diversity of  
10 technologies [5]. Island economies often rely strongly on tourism, with a strong impact on structure  
11 and variability of the energy demand [4].

12 Renewable energy (RE) technologies provide solutions for a more sustainable and self-sufficient  
13 energy supply [6, 7]. However, the possibilities to balance fluctuations in power generation and  
14 demand through interregional electricity transmission are typically very limited or not available at all  
15 in island systems. Consequently, other flexibility options must be employed, including storage,  
16 demand response (DR) as well as synthetic fuel production [6, 7]. Considering this, island solutions  
17 can act as role models for future energy transition in larger systems.

18 Supply systems predominantly or fully reliant on RE technologies have been studied for various  
19 countries and islands. On a European level, the impact of different balancing technologies on  
20 electricity supply and costs has been assessed previously for RE shares of up to 80% [8]. In this work,  
21 grid could reduce costs at high RE shares, whereas storage was not cost-efficient. For Portugal, a  
22 100% RE power supply system has been designed before, treating the country as an island system  
23 with no international electricity exchange [9]. The possibility of a fully renewable power supply has  
24 been evaluated as well for France, showing a significant need for flexibility options along with  
25 imports and DR [10]. For the United Kingdom, an analysis of the future power supply in high  
26 temporal and spatial resolution found that for more than an 80% RE share to be economically  
27 feasible, large-scale storage, significantly more power imports, or domestic dispatchable renewables  
28 must be available [11]. These studies were limited to power supply and did not consider energy  
29 demands of other sectors. For Ireland, it has been shown that electricity, heating, and transport  
30 demands can be completely supplied by RE [12]. Owing to the abundant availability of biomass,  
31 intermittent technologies played only a minor role in this work. With the analysis relying on the  
32 application of a detailed energy system model, it did not provide any cost assessment. In a  
33 subsequent study, the cross-sectoral transition towards 100% RE supply in Ireland has been  
34 described in more detail, including an economic assessment [13]. There, wind power was rated most  
35 important future energy source, whereas photovoltaics (PV) and ocean energy were not considered.  
36 Considering the whole energy system, a 100% RE supply has been designed for Denmark as well [14].  
37 All these national studies did not evaluate internal power transmission.

38 Specifically for island energy systems, the RenewIsland methodology introduced in [15], provides a  
39 framework for mapping demand and supply of energy and water as well as the development of  
40 scenarios. Amongst other, it has been applied to Cozumel/Mexico, Porto Santo/Portugal, and  
41 Mljet/Croatia [16]. The model relies on a merit order approach and does not optimise the layout and  
42 operation of the system components. Based on high resolution data, potential supply cost reductions

43 that can be achieved by RE technologies have been identified on almost 1800 small islands globally  
44 [17]. However, this analysis was limited to the power sector and did not consider other balancing  
45 technologies than battery storage and diesel generators. A more detailed comparison of electricity  
46 demand and RE potentials has been provided for Salina/Italy [18]. Similarly, it has been shown that  
47 up to 90% of the electricity demand of Dia/Greece can be supplied by RE technologies [19]. This work  
48 proposed to use surplus generation from intermittent resources for seawater desalination. By  
49 adjusting their operation to the availability of intermittent RE, desalination plants can enable supply  
50 cost reductions [20]. Applying a power system model in hourly resolution to the island of  
51 Lesbos/Greece, it has been found that a grid connection to the mainland can reduce supply costs and  
52 enable higher wind shares [21]. The importance of energy storage in island systems has been  
53 highlighted in a cross-sectoral case study for an imaginary island, [22]. All these studies are limited to  
54 the assessment of energy demand and RE potentials, but do not provide a scenario of how to  
55 transform the energy supply system.

56 The available studies on sustainable energy systems and islands are limited mostly to the power  
57 sector, and do not reflect the advantages of linking power, heat, transport, and water supply.  
58 Furthermore, previous works did neither consider the supply potentials across the large bandwidth  
59 of RE technologies, nor provide pathways towards a 100% RE supply system. Instead, they focused  
60 either on the final or intermediate stages of the system transformation. Our paper closes this gap by  
61 providing a novel approach to the development of cross-sectoral transformation pathways towards a  
62 100% RE system, focusing on a potential supply structure for the future local energy demand. We  
63 therefore combine a long-term outlook on transformation pathways with a detailed insight in the  
64 interdependencies of an interconnected energy system based mostly on fluctuating power sources.  
65 Additionally we focus on connecting neighbouring island power systems to provide insight beyond  
66 existing research. We apply this approach to the Canary Island archipelago, which represents an  
67 example for a remote island system of relevant size [23]. The archipelago with 2.2 million inhabitants  
68 is situated west of the African coast and politically part of Spain. Starting with Lanzarote and  
69 Fuerteventura, situated 100 km west of Morocco, the archipelago stretches out more than 300 km to  
70 the west across seven islands. Gran Canaria and Tenerife at the centre are the largest islands with a  
71 population of 0.85 million and 0.89 million people, respectively. Further to the west the archipelago  
72 extends to the smaller islands La Gomera, La Palma, and El Hierro. Tourism is the main economic  
73 sector and concentrated in the four larger islands. It is strongly developing, with guest-nights  
74 increasing from 11 million in 2010 to 14 million in 2014 [24], putting additional pressure on the  
75 energy system. The Canary Islands are part of a cluster of near tropical islands, featuring high solar  
76 irradiation, low precipitation with high seasonality. The seven islands feature low PV and wind  
77 generation costs at high generation rates and represent a large variety in population density and land  
78 availability[23]. As for many other islands and archipelagos, so far the Canary Islands' energy supply  
79 depends almost totally on oil imports [25]. Alternatives are being assessed or promoted, including RE  
80 sources, natural gas imports and an improved grid connection between the islands [25, 26]. While  
81 transformation scenarios are already available on national level for Spain [27], they cannot directly  
82 be transferred to the remote Canary archipelago. One of the few previous studies dedicated to the  
83 archipelago's energy supply proposed a wind powered pumped hydro system for the island of Gran  
84 Canaria [28]. Furthermore, the complementarity of natural gas and renewables in the Canary Islands  
85 has been evaluated, suggesting that both supply risks and costs are lowest in a balanced mix of both  
86 [5]. So far, no comprehensive long-term study of a sustainable energy supply in the Canary Islands is  
87 available. Starting from the current energy system, we elaborate a transformation pathway towards

88 a 100% RE supply in the year 2050, considering RE and efficiency potentials as well as  
89 interdependencies between power, transport, and heating sectors.

90 The present paper is structured as follows: Section 2 gives an overview over the current energy  
91 system in the Canary Islands. Section 3 introduces the two applied models Mesap-PlaNet for long-  
92 term modelling and REMix for optimisation with high resolution as well as their calibration and  
93 linkage for this study. The model input data is described in Section 4. Model results including supply  
94 structures and impacts on CO<sub>2</sub> emissions are presented in Section 5 and discussed in Section 6.  
95 Finally, the main conclusions from the results are drawn in Section 7.

## 2 The Canary Island energy system

96 The Canary Island's government provides detailed statistics on the local energy system [25].  
97 Currently this system is characterised by a heavy dependence on oil imports, delivering 99% of  
98 primary energy. Oil is used for power generation, heat production and land transportation. Road  
99 traffic accounts for 45% of internal final energy consumption, such as the residential, service, and  
100 commerce sectors, while industry plays a minor role (6%). Renewables are still in the beginning of  
101 their development, providing 7% of power and 2% of heat supply. However, a broad range of  
102 renewable technologies is already available, including PV, wind energy, hydropower, and solar  
103 thermal collectors.

104 Table 1 shows the recent development of the main energy-economic indicators in the archipelago,  
105 which saw considerable variations during the last years. Energy intensity in the power sector is higher  
106 than in the Spanish mainland, nonetheless efficiency improvements are targeted by the government  
107 by subsidies, as a means to reduce CO<sub>2</sub>-emissions [25].

**Table 1: Energy intensity and per capita demand in the Canary Islands [25].**

	primary energy	final energy	Intensity (primary energy)	Intensity (final energy)	per capita
	PJ	PJ	GJ/€	GJ/€	GJ/cap
2011	207	151	4.96	3.60	71
2012	235	147	5.66	3.53	69
2013	221	137	5.47	3.39	65

108 The energy sector is the main GHG emitter in the Canary Islands. Starting at about 8 kt CO<sub>2</sub>-  
109 equivalents (eq) in 1990, total emissions peaked between 2005 and 2008 about 16 kt CO<sub>2</sub>-eq, of  
110 which 90-92% resulted from the energy sector. Since then, emissions have been decreasing by 10-  
111 15%, coinciding with the economic crisis. In the same period, emissions from the energy sector even  
112 declined by 25%. Per capita emissions are also declining, adding up to 6.3 t CO<sub>2</sub>-eq/cap in 2012.

113 These figures show that efforts for decreasing emissions are increasingly effective. Still, it is a long  
114 way towards a sustainable energy system for the archipelago. Applying our modelling approach, we  
115 are shaping a scenario for a potential pathway towards a more sustainable energy supply, integrating  
116 efficiency and RE potentials.

## 3 Methodology

117 For the analysis of a 100% RE system in the Canary Islands, we enhance our modelling approach by  
118 linking the long-term energy system balancing tool Mesap-PlaNet with our deterministic high-

119 resolution energy system optimisation model REMix (Figure 1). Both models are introduced in the  
 120 following as well as the link between them and the scenario approach for assessing future  
 121 development pathways for the energy system.




Figure 1: Modelling approach

### 3.1 Scenario approach and model coupling

122 The development of the future energy demand is assessed in an explorative scenario approach.  
 123 Based on that, we apply a normative scenario approach to evaluate the restructuring of the energy  
 124 supply system. Starting with a target of a 100% RE system in 2050, we develop a transformation  
 125 scenario in a back-casting process, evaluating the steps that are necessary to achieve the target.

126 The long-term outlook performed with the Mesap-PlaNet model is technology driven and focuses on  
 127 interdependencies of the sectoral transformation in the long-term as well as diversification of the  
 128 energy system. The model is balancing the annual energy demand and supply for the whole  
 129 archipelago in 5-year steps. While this method provides annual energy balances for heat, transport,  
 130 and power sectors, it lacks a detailed insight in the complex interrelations of intermittent power  
 131 generation and demand curves, respectively their geographical interconnection via power grids and  
 132 the temporal balancing via storage. For this reason, the cross-sectoral approach is back-filled with  
 133 detailed optimisation of the power sector for the year 2050 with REMix. The model assesses least-  
 134 cost composition of generation, grid, and storage capacities in high spatial resolution, and provides  
 135 an evaluation of the hourly system dispatch. By using REMix, we analyse three sub-scenarios for a  
 136 100% renewable system, focusing on different balancing options for variable renewable power  
 137 (Section 4.5).

138 To combine the two models, we apply an iterative modelling approach.

- 139 1. Development of a business-as-usual energy demand scenario and assessment of efficiency  
140 potentials within the industrial, transport, and other sectors.
- 141 2. Determination of the least-cost power supply technology mix for the year 2050 and 100% RE,  
142 including secondary power demand from transport and heat production with REMix.
- 143 3. Development of the transformation pathway for the whole energy system with Mesap-  
144 PlaNet, using the REMix results of energy outputs, installed capacities, and load factors

### ***3.2 Mesap-PlaNet model***

145 The overall energy system of the Canary Islands is represented within the Mesap-PlaNet energy  
146 simulation model [29, 30]. This bottom-up accounting framework can be applied for the calculation  
147 of annual energy system balances [31, 32]. The Mesap-PlaNet flow calculation uses a set of linear  
148 equations, which are solved sequentially. The model requires a consistent exogenous definition of  
149 feasible developments for each sector and technology.

150 Starting with externally defined drivers such as GDP and, the model first calculates the demand for  
151 energy services via intensities, including electricity consumption per capita and industrial heat  
152 demand per unit of GDP. As a result, useful heat demands as well as electricity demands are  
153 determined for three sectors: industry, transport, and “Other Sectors”, which comprise residential,  
154 agriculture, service, and commerce. Each sector is represented by set of available technologies, both  
155 renewable and fossil. Backbone of the model is a technology database, defining parameters for  
156 intensity, efficiency, fuel input, CO<sub>2</sub> emissions, full-load hours, and – in the case of power  
157 technologies also investment costs and life time.

158 By using assumptions and background information about technical and structural development  
159 options for the energy system transformation, and considering potential barriers and limits such as  
160 RE potentials, consistent development paths are defined and integrated into the model database  
161 (Section 4). This scheme allows for the integrated calculation of energy flows from demand drivers to  
162 primary energy consumption. Eventually, the model calculates future energy balances with primary  
163 energy consumption, sectoral CO<sub>2</sub> emissions, and power generation cost in five year steps until 2050.

### ***3.3 REMix model***

164 REMix provides a simplified representation of the power system, including demand, renewable and  
165 conventional generation as well as storage, DR, and power transmission<sup>1</sup>. The model is not limited to  
166 the power sector, but also contains demand and supply of heat as well as synthetic fuels, and electric  
167 mobility. The model input comprises techno-economic technology parameter, scenario parameter  
168 (e.g. installed power plant capacities) as well as spatially resolved climate and weather data for each  
169 hour of the year. The latter is used in the energy data analysis tool REMix-EnDAT for the calculation  
170 of hourly wind and solar power production profiles. Relying on this input data and using linear  
171 optimisation, REMix-OptiMo assesses the least-cost composition and operation of the energy system  
172 during one year. The minimised costs comprise all expenditures arising from the installation of new  
173 assets and the operation of all assets, thus capital costs, fuel costs as well as other variable  
174 operational costs. Model results comprise the installation of new assets, the hourly operation of all

---

<sup>1</sup> This paragraph relies on [33, 34]

175 assets, supply costs, and CO<sub>2</sub> emissions. REMix is a multi-node model. Demand and supply within  
 176 predefined geographical regions are aggregated to model nodes, which can be connected through  
 177 electricity grids. Within the nodes, all generation units of each technology are grouped and treated as  
 178 one single asset. The model relies on a perfect foresight modelling approach and optimises over the  
 179 overall time horizon.

180 Within REMix, each technology class is represented by an independent module, containing  
 181 parameters, variables, equations, and inequalities required for the representation of respective  
 182 technical and economical characteristics. The model application presented in this work uses the  
 183 technology modules of intermittent RE, concentrating solar power (CSP), geothermal power,  
 184 conventional power plants, combined heat and power (CHP), electric and thermal storage as well as  
 185 direct current (DC) power transmission, DR, hydrogen production, electric heating, and electric  
 186 mobility. Mathematical descriptions of these modules can be gathered from [33-35].

## 4 Data

187 The calculation of the target-oriented scenarios is based on the development of detailed input data  
 188 sets considering efficiency and RE potentials as well as technical parameters of power, heat, and  
 189 synthetic fuel production technologies.

190 In a first step, the general Mesap-PlaNet model was adapted, calibrating model inputs and results for  
 191 the starting year against statistical data for the Canary Islands for 2013 [25]. Where no data was  
 192 available, the calibration was based on IEA energy balances for Spain for 2013 [36]. Technology data  
 193 is based on previous model applications for the EU-28 [37] and adapted according to Section 4.3.

### 4.1 Projection of the final energy demand

194 Economic development and population growth are important drivers for the future of the final  
 195 energy demand [31, 38]. Future population development is an important factor because population  
 196 growth affects the size and composition of the energy demand, directly and through its impact on  
 197 economic growth and development.

#### Population

198 The population projection is based on the Spanish projection for population development and the  
 199 long-term trend of Canary Islands' share in Spanish population [24] (Table 2). Tourism as a major  
 200 economic factor is also projected by using a simplistic approach based on available statistics of  
 201 tourist numbers, average and total cost of stays [39], and the availability of hotel beds [40]. We  
 202 calculate that guests currently represent an equivalent of about 10% of the population (cap eq.),  
 203 increasing by one fourth during the last four years. For trend projection we assume a slowdown of the  
 204 current trend of increasing tourism, resulting in a doubling of guest nights by 2050.

**Table 2: Population development projections in the Canary Islands (based on statistics [19–21] and own assumptions)**

		2013	2015	2020	2025	2030	2040	2050
<b>Population</b>	<b>Mio. cap</b>	2.12	2.12	2.15	2.17	2.18	2.19	2.21

<b>Tourism</b>	<b>Mio. cap eq.</b>	0.21	0.23	0.24	0.27	0.31	0.37	0.39
----------------	---------------------	------	------	------	------	------	------	------

### **Economic growth**

205 For projection of future economic development we apply growth trends for Europe from previous  
 206 studies, calibrated with current statistical data for Spain and the Canary Islands. GDP in Europe (EU-  
 207 28) is assumed to grow by about 1.6% per year over the projection period until 2050 [37]. For the  
 208 Canary Islands GDP, we apply the same growth rate, allocating a constant share of 3.9% of the  
 209 Spanish GDP to the archipelago as between 2007 and 2011 [41].

### **Final energy demand**

210 GDP and population drive the final energy demand scenario until 2050, applying the same  
 211 improvements in energy intensities for industry, transport, and other sectors as for EU-28 [37]. Based  
 212 on population, GDP and intensities, Mesap provides a projection for electricity and fuels in each  
 213 sector for a Business-as-usual (BAU) case. To address local developments in the Canary Islands, the  
 214 resulting final energy demand is then adapted with local information: Short-term development of  
 215 electricity demand include projections for the archipelago by the Spanish government [26]. Mid-term  
 216 prospects until 2030 for the electricity demand are based on the trends described in a Spanish  
 217 energy scenario study [27].

### **Energy efficiency potentials**

218 Efficient use of energy is a precondition for a sustainable energy system and a major driver to reduce  
 219 the energy demand. Potentials for a more efficient energy use are yet largely to be exploited, but the  
 220 markets for efficiency measures is developing strongly [42]. Efficiency potentials for the industrial  
 221 and other sectors have been assessed in [43]. Details about assumptions for energy efficiency  
 222 improvement in industries and other sectors can be found in [44]. Based on the above described BAU  
 223 scenario we apply these efficiency potentials in industry and other sectors in the Canary Islands  
 224 gradually until 2050, starting from 2020. BAU scenario and efficiency scenario for the final energy  
 225 demand are both presented and compared in Section 5.1.

### **Transport demand**


226 Concerning transport demand, the Canary Islands differ strongly from a mainland system in two  
 227 major aspects. On the one hand, road transport in the islands covers comparatively small distances  
 228 with its longest island Fuerteventura stretching just about 100 km. Therefore a main constraint in the  
 229 mainland – the still low range of battery electric vehicles (BEV) – does not apply in the archipelago,  
 230 making a quick introduction of electric mobility technically feasible. On the other hand, due its  
 231 remote situation the archipelago relies strongly on aviation and navigation for goods and people to  
 232 reach the islands. The importance of tourism in the island economy is further increasing the  
 233 dependency on aviation. Thus a modal shift towards more efficient means of transport such as ships  
 234 and rail is not feasible. As there is no data available for a disaggregation of air and ship traffic  
 235 between mainland and interisland traffic, we restricted our scenario to the land transport demand in  
 236 the Canary Islands.

237 Transport assumptions are based on a study for the EU-28 [32, 37]. Starting with the BAU transport  
 238 demand, we assume a demand reduction in light duty vehicles by about 20% and heavy duty vehicles

239 by about 10% by 2050, achieved by efficient transport planning and modal shifts towards non-fuel  
240 transport. A shift to more efficient power trains and a gradual switch to highly efficient electric and  
241 fuel cell engines provide additional potentials. Based on the EU-28 transport scenario, by 2050 up to  
242 63% of light duty vehicles will rely predominantly on electric propulsion and 37% on hydrogen fuel  
243 cells. For heavy duty vehicles, we apply shares of 25% for electric and hybrid vehicles, and 75% for  
244 fuel cell propulsion based vehicles.

## 4.2 Model regions considered

245 In REMix, the Canary Island electricity system is not considered as a whole, but subdivided to nine  
246 model regions. The islands of El Hierro, La Palma, La Gomera, Fuerteventura, and Lanzarote are  
247 represented as one model region each, whereas the two biggest islands Gran Canaria and Tenerife  
248 are split into a northern and a southern part at latitude  $27^{\circ}57'$  and  $28^{\circ}15'$ , respectively (Figure 2).  
249 This regional subdivision allows for an analysis of the contribution of grid interconnections to the  
250 balancing of RE fluctuations and achievement of supply cost reductions.



**Figure 2: Model regions, sea depth, and possible grid connections. In scenario RE Base and DR-, only the green connections can be built, whereas in scenario Grid+ the red ones are available as well.**

## 4.3 Renewable energy potentials and power plant capacities

251 Owing to the small island surface, RE potentials are fairly limited in the Canary Island archipelago.  
252 This applies to the installable capacities of hydro and biomass power in particular, but also to solar  
253 and wind power. However, the latter are available with a fairly good resource quality compared with  
254 other regions in Europe. Given the volcanic activity, there is also some potential for geothermal  
255 power generation.

256 Previous studies provide detailed assessments of the potentials for PV [45, 46], onshore wind power  
257 [47, 48], floating and fixed foundation offshore wind power [49], geothermal energy [50], biomass  
258 energy [51, 52], and wave energy [53-55]. Wave power can be used close to all islands except for La  
259 Gomera. While PV, wind and biomass are available in all islands, geothermal energy is only available  
260 in Tenerife and Gran Canaria. The hydrological plans for the islands of La Palma and Tenerife [56]  
261 include information of currently operating and planned run-of-river hydro power stations. However,  
262 these are very limited in their capacity, and additional potentials are not identified.

263 We evaluate the potential for CSP by using REMix-EnDAT. Its application relies on the resource data  
264 and technology characteristics documented in [57, 58]. The model identifies installable capacities of  
265 CSP only in the easternmost islands of Fuerteventura, Lanzarote, and Gran Canaria. We furthermore

266 apply REMix-EnDAT for the calculation of region-specific hourly power generation profiles of CSP, PV,  
 267 and wind power plants. They are calculated from weather data of the year 2001, which exhibited an  
 268 average annual availability for wind and solar power compared with other years in the considered  
 269 period 1984-2004. The normalised hourly load profiles rely on metered data of the year 2013.

270 According to the scenario development premises, we assume that all available RE sources will be  
 271 exploited in the future. In the REMix analysis for the year 2050, we evaluate the least-cost mix of the  
 272 RE technologies with highest potential – CSP, PV, and wind power. This is done by providing the  
 273 maximum installable capacities as input and considering a model-endogenous capacity expansion.  
 274 For wind energy, we model three different technologies: onshore, floating offshore, and fixed  
 275 foundation offshore. Available potentials of CSP, PV, and wind power are summarised for each  
 276 technology and region in Table 3.

**Table 3: Maximum installable generation capacities of PV, CSP, and wind power.**

	PV	CSP	Wind onshore	Wind offshore fix	Wind offshore floating
	MW	MW (th)	MW	MW	MW
El Hierro	39	0	58	107	342
Fuerteventura	477	8892	1824	846	2592
Gran Canaria N	882	406	269	33	151
Gran Canaria S	1323	1117	627	299	1359
La Gomera	67	0	106	139	696
La Palma	224	0	116	171	771
Lanzarote	581	2157	512	589	1660
Tenerife N	1438	0	155	86	283
Tenerife S	1438	0	233	342	1131
Total	6468	12572	3900	2612	8985

277 Owing to their limited potential and low technology development, respectively, we assume that run-  
 278 of-the-river hydro power, geothermal power, and wave energy provide only small amounts of  
 279 electric energy. For this reason, their power generation capacities are not endogenously determined,  
 280 but provided as input to the model. The same applies to biomass and fuel cell CHP units, which  
 281 supply heat to industrial and commercial loads. Table 4 contains the considered power generation  
 282 capacities.

**Table 4: Installed capacities in the year 2050 according to the available potentials.**

	Run-of- the-river	Geothermal	Wave	Biomass CHP	Fuel Cell CHP	Pumped storage hydro	
	MW	MW	MW	MW	MW	MW	MWh
El Hierro	0	0	3	0.14	0.02	12	84
Fuerteventura	0	0	19	1.82	0.32	0	0
Gran Canaria N	0	0	3	8.36	1.52	131	788
Gran Canaria S	0	100	0	3.34	0.69	910	5462
La Gomera	0	0	0	0.29	0.05	0	0
La Palma	1.2	0	9	1.11	0.21	200	1200
Lanzarote	0	0	16	2.31	0.41	0	0
Tenerife N	2.0	50	12	8.91	1.61	699	5381

Tenerife S	0.3	50	0	3.51	0.71	305	1831
Sum	3.5	200	62	29.79	5.53	2322	15133

283 The techno-economic specifications of power generation as well as storage technologies are  
284 summarised in Table 6 in the Appendix. Data sources are reported in detail in previous publications  
285 of REMix analyses [35, 59].

#### 4.4 *Transmission, storage, and demand response*

286 Most RE potentials in the Canary Islands rely on solar irradiation and wind, and are thus of fluctuating  
287 nature. The balancing of their temporal variation in power generation poses the major challenge to a  
288 100% RE supply. This may include both spatial balancing by the power grid and temporal balancing by  
289 energy storage and DR.

290 Currently, only Lanzarote and Fuerteventura are electrically connected through a seabed cable. The  
291 transmission system operator Red Eléctrica de España plans to install additional connections  
292 between La Gomera and Tenerife as well as between Fuerteventura and Gran Canaria [26]. Given the  
293 great sea depth and rough seabed (Figure 2), connections between all other islands are much more  
294 difficult to realise and currently not considered. In the REMix optimisation, DC cables between  
295 neighbouring model regions can be endogenously installed. Whether this includes all connections  
296 between all islands or only that already available or planned depends on the sub-scenario (Section  
297 4.5). According to [60], we assume DC transmission losses of 0.27%/100 km in sea cables. An  
298 additional loss of 0.7% occurs at conversion from and to alternating current. Investment costs  
299 amount to 2000 k€/km and 150 000 k€ for each converter station. All components have an  
300 amortization time of 40 years and annual fixed operational costs equivalent to 0.6% of the  
301 investment.

302 In the present study, we consider three different electricity storage technologies: pumped storage  
303 hydro (PSH), vanadium redox-flow batteries, and hydrogen tank storage. Given the mountainous  
304 surface of most islands and the availability of many water reservoirs, significant potential for an  
305 installation of PSH is available in the Canary Islands. It is quantified based on the hydrological plans  
306 for each island [56] and considered as being exploited by 2050. The resulting installed capacities  
307 concentrate in the islands of Tenerife and Gran Canaria as listed in Table 4.

308 In contrast to PSH, capacities of battery and hydrogen storage are endogenously optimised by REMix  
309 and not subject to any upper limit. Owing to the usage of hydrogen in CHP, industry and transport,  
310 the model input considers some electrolyser capacities. We assume that these are equipped with a  
311 storage dimensioned to store 12 hours of hydrogen production. To use hydrogen for dispatchable  
312 power generation, additional storage, and electrolyser capacity can be added by the model. For re-  
313 electrification, these must be complemented by an investment in hydrogen-fired gas turbines or  
314 combined cycle gas turbines (CCGT). The REMix assessment also considers thermal energy storage  
315 (TES). To allow some adjustment of their operation to the available intermittent RE, we assume that  
316 all CHP and electric heat production technologies are equipped with a TES designed to store four  
317 hours of peak heat supply.

318 DR is considered for desalination, BEV charging, cement production, cooling, and air conditioning as  
319 well as the flexible operation of hydrogen electrolysis. Uncontrolled load shedding is not considered  
320 in the model. This implies that all other demand must be covered in every hour of the year. The

321 analysis of desalination in the Canary Islands relies on [61-64]. We assume that desalination can be  
 322 used for electric load shifting, which is technically possible for plants applying reverse osmosis.  
 323 However, it requires a more generous plant capacity layout compared to today as well as the  
 324 availability of freshwater storage. We consider a dimensioning, which allows for an annual  
 325 production within 5000 full-load hours. Load shifting is possible within a time period of up to 48 hours,  
 326 and storage for twelve hours of average production is assumed to be available in all plants. We apply  
 327 an increase in the electricity demand of 0.5% per hour of load shift. We estimate DR potentials of  
 328 cement production, air conditioning as well as cooling in industry and the commercial sector  
 329 according to the methodology presented in [65]. Additional data sources include [25, 66]. The  
 330 duration of load interventions is limited to one hour for air conditioning, six hours for cooling and 48  
 331 hours for cement production. For BEV, we assume that the charging capacity equals 1.5 times the  
 332 maximum demand at uncontrolled charging (details on modelling and data are reported in [33]).  
 333 Here, a delay in charging by up to eight hours is considered. Table 5 provides the maximum load  
 334 reduction potential of all considered DR options. BEV charging, heat demand and hydrogen demand  
 335 profiles are considered according to [33].

**Table 5: Average load reduction potential of the available DR measures.**

	Desalination	Cooling	Air Conditioning	BEV	Cement	Electrolysers
	MW	MW	MW	MW	MW	MW
El Hierro	1.9	0.05	0.3	0.5	0	3.9
Fuerteventura	14.2	1.73	4.6	5.5	0	48.7
Gran Canaria N	46.9	2.83	12.2	32.9	1.5	102.0
Gran Canaria S	46.9	2.81	9.4	10.5	0	69.1
La Gomera	2.0	0.15	0.5	1.1	0	35.4
La Palma	11.8	0.45	1.9	4.3	0	36.8
Lanzarote	16.0	1.99	5.1	7.2	0	41.9
Tenerife N	35.0	3.52	14.3	34.2	0	135.1
Tenerife S	35.0	2.90	8.6	11.1	1.2	169.8

#### 4.5 Scenario variations in the REMix assessment

336 To assess the importance of different balancing technologies in least-cost supply structures, we  
 337 analyse three sub-scenarios with REMix. They differ in the availability of DR and the feasibility of grid  
 338 connections.


- 339 • **RE Base:** Grid connections between islands are limited to those currently available, planned  
 340 or considered as technically feasible. This implies a possible exchange between Gran Canaria,  
 341 Fuerteventura, and Lanzarote as well as between Tenerife and La Gomera. In contrast, El  
 342 Hierro and La Palma cannot be connected to any other island and a connection of the two  
 343 major islands of Tenerife and Gran Canaria is not possible (Figure 2).
- 344 • **DR-:** Scenario DR- relies on the same grid connections as the RE Base scenario, but sets aside  
 345 load shifting of desalination, BEV charging, cement production, cooling, and air conditioning.
- 346 • **Grid+:** This scenario includes an enhanced grid extension. In contrast to the RE Base scenario,  
 347 grid connections are assumed feasible between all islands, thus providing one integrated

## 5 Results

349 In the following, we present scenario results along the modelling chain. Starting with the evaluation  
 350 of the final energy demand and potential efficiency gains (Section 5.1), we then present the results of  
 351 the REMix optimisation for 2050, focusing on the optimised mix of power plants and their regional  
 352 disaggregation (Section 5.2). Finally, we provide an overview of the transition pathway for the whole  
 353 archipelago (Section 5.3). Additional results are reported in [67].

### 5.1 Energy demand

354 GDP and population growth can be expected to drive the final energy demand from 92 PJ in 2012 to  
 355 about 131 PJ in 2050 under BAU conditions, representing an increase of 42% (Figure 3). Main drivers  
 356 are the residential and commercial sector, aggregated under other sectors. This development reflects  
 357 the expected increase in tourism (Section **Fehler! Verweisquelle konnte nicht gefunden werden.**).  
 358 The final energy demand in land transport remains stable, as the increased transport demand is  
 359 compensated by higher efficiency. The same holds true for the industry sector.




**Figure 3: Final energy demand by sector under the BAU and the 100% renewable energy scenario (RE Base) disaggregated by sectors**

360 If efficiency measures are consequently applied across all sectors, a decrease in energy demand can  
 361 be achieved. In the 100% RE scenario (RE Base), the final energy demand drops to 58 PJ/a by 2050.  
 362 However, electrification of heating and transport increases the power demand from 8.7 TWh in 2013  
 363 to 15.6 TWh in 2050. Improved living standards (e.g. additional appliances for cooling and additional  
 364 water desalination), and electric heating lead to higher power demands in industry (+26%) and other  
 365 sectors (+17%).

### 5.2 The power sector in 2050

366 REMix provides the least-cost composition of the power supply structure in 2050 as well as the  
 367 hourly system operation. Overall power generation capacities reach 11.3 GW in scenario Grid+, 12.1  
 368 GW in RE Base, and 12.2 GW in DR-, equivalent to between 320% and 350% of the annual peak load.

369 All sub-scenarios are dominated by solar PV, which accounts for approximately half of the installed  
 370 capacity. Second highest capacities are found for wind power with shares between 28% and 37%.  
 371 Figure 4 shows that the possibility to connect all islands reduces the overall size of the power plant  
 372 park, and also changes its composition: Floating offshore wind turbines are not applied at all, and  
 373 fixed offshore wind turbines are reduced. These reductions are compensated by a higher installation  
 374 of CSP, which is almost twice as high as in the other scenarios, and onshore wind. The model-  
 375 endogenous installation of hydrogen-fired CCGT reaches between 424 MW (Grid+) and 613 MW (DR-  
 376 ), which is about 5% of the total generation capacity.




**Figure 4: Total installed power generation capacity in the three sub-scenarios. *Other RE* contains geothermal, biomass, hydro and wave power as well as fuel cells (Table 4).**

377 The regional allocation of power generation capacities is shown for scenario RE Base and Grid+  
 378 Figure 5 and Figure 6, respectively. The results of scenario DR- are very similar to those of scenario RE  
 379 Base. In all scenarios, onshore wind, PV and, and CCGT are applied on all islands, whereas CSP and  
 380 offshore wind show regional concentrations. CSP is installed on all islands with a technical potential –  
 381 Lanzarote, Gran Canaria, and Fuerteventura. The capacity on the first two islands is not affected by  
 382 the availability of grid and DR, whereas in Fuerteventura it is more than doubling in scenario Grid+. In  
 383 scenario RE Base and DR-, about 91% of the offshore wind capacities are located in the subsystem  
 384 composed of the islands of Tenerife and La Gomera, the remaining 9% in La Palma and Gran Canaria.  
 385 With the additional grid available in scenario Grid+, remaining offshore wind capacities are found in  
 386 Tenerife (60%), Gran Canaria (13%), and La Palma (27%). The technology shift from offshore wind to  
 387 onshore wind and CSP enabled by the availability of more grid connections causes a significant shift  
 388 of generation capacities from La Gomera and Tenerife to Fuerteventura.

389 Comparing the model-endogenous capacity installation with the available potentials (Table 3) it  
 390 appears that PV potentials are fully exploited in all scenarios and model regions except Lanzarote.  
 391 Onshore wind potentials are also exploited mostly, except for those in Lanzarote, Fuerteventura, and  
 392 El Hierro. Offshore wind power capacities reach their limits almost exclusively for fixed turbines, in  
 393 the scenarios with limited grid expansion and in Tenerife, La Gomera, and La Palma. CSP potentials  
 394 are fully exploited in Gran Canaria in all scenarios, but not in Lanzarote and Fuerteventura in any of  
 395 the scenarios. The comparison of potentials and required capacities reveals that additional  
 396 renewable power generation would be possible in most islands. However, for the least-cost

397 technologies of PV, onshore Wind and, and CSP, remaining potentials are almost exclusively found in  
 398 the easternmost islands of Lanzarote and Fuerteventura.



399  
 Figure 5: Power plant and grid capacities in scenario RE Base.






Figure 6: Power plant and grid capacities in scenario Grid+.

400 Figure 5 and Figure 6 compare the model-endogenous installation of power connections between  
 401 model regions and scenarios. Overall transmission capacities reach 746 MW in scenario RE Base,  
 402 763 MW in DR- and 1195 MW in Grid+. A possible connection of all islands increases the grid capacity  
 403 by about 450 MW, and decreases the required generation capacity by twice this amount. The REMix  
 404 results displayed in Figure 6 highlight that the most important connections are those between the  
 405 three major islands Gran Canaria, Tenerife, and Fuerteventura as well as within Tenerife.



**Figure 7: Total installed storage capacity in the three sub-scenarios: generation capacity (left scale) and energy content (right scale).**


406 Figure 7 shows the necessary storage demand under the three scenarios. It reaches up to 3 GW of  
 407 converter capacity and 300 GWh of energy content, which are equivalent to about 85% of peak load  
 408 and 2% of the annual power demand, respectively. The converter capacity is dominated by PSH,  
 409 whereas the energy capacity is highest for hydrogen storage. Additional grid connections in scenario  
 410 Grid+ reduce the required hydrogen storage almost by half and eliminate all battery storage demand.  
 411 On the contrary, more battery and hydrogen storage is needed if no DR can be realised. Hydrogen re-  
 412 electrification in CCGT is used in all islands (Figure 5 and Figure 6), whereas battery storage is  
 413 installed only in La Gomera and southern Tenerife.



**Figure 8: Total power generation in the three sub-scenarios. Other RE comprises biomass, hydro, wave power, and fuel cells.**


414 Figure 8 shows the power generation structure in the three sub-scenarios. According to potentials  
 415 and capacities, it is dominated by wind and solar power. In the scenarios RE Base and DR-, wind and  
 416 solar provide about 45% of the overall generation each. Two thirds of solar power is generated by PV,  
 417 one third by CSP. Additional grid connections available in scenario Grid+ enable a significant shift  
 418 from offshore wind to CSP generation. Both overall generation and dispatchable CCGT operation are  
 419 significantly higher when DR and transmission are not available. Owing to additional storage losses,

420 the overall generation is by more than 1 TWh higher in scenario DR- than in scenario Grid+.  
 421 Furthermore, the contribution of hydrogen-fired CCGT to power supply reaches less than 1% in  
 422 scenario Grid+, and almost 3% in DR-. The operation of all other technologies is influenced only to a  
 423 minor extent by the scenario assumptions. Geothermal power generation contributes about 1.3  
 424 TWh, which is equivalent to 8% of the total generation. Annual generation of other technologies are  
 425 much lower at about 160 GWh for biomass CHP, 70 GWh for wave power, 40 GWh for fuel cells,, and  
 426 15 GWh for hydro run-of-river power.



**Figure 9: Annual storage output and load shifting in the three sub-scenarios. Hydrogen storage output reflects the power generation in CCGT.**


427 According to the REMix results, electricity storage and DR contribute significantly to the balancing of  
 428 fluctuations in wind and solar power generation (Figure 9). Annual storage output reaches 0.6 TWh in  
 429 scenario Grid+, 0.9 TWh in RE Base, and 2.9 TWh in DR-, which is equivalent to between 3% and 16%  
 430 of the overall power generation (Figure 7). When available, DR is used extensively for shifting electric  
 431 loads, especially by modifying the charging of BEV and operation of reverse osmosis desalination  
 432 plants. Overall load shifting accounts for about 1.8 TWh in both scenarios RE Base and Grid+.  
 433 Maximum load reduction by desalination reaches 0.21 GW, the BEV charging load varies between  
 434 0–0.43 GW. In scenario DR-, load shifting is completely substituted by PSH, battery, and hydrogen  
 435 storage. Additional balancing is provided by flexible operation of electrolyzers and electric heating.  
 436 During the year, their electricity demand varies between 0–1.85 GW and 0–0.21 GW, respectively.



**Figure 10: Annual electricity exchange between the model regions in the three sub-scenarios. Values greater than zero imply a net import, those smaller than zero a net export of electricity.**

437 Power exchange between the islands is a major factor within all considered scenario variations.  
 438 Figure 10 shows that between 30% and 34% of the total power demand are transferred over at least  
 439 one region border. Highest electricity import and exports naturally occur in the Grid+ scenario with  
 440 about 5.3 TWh. Most important import regions are the northern parts of Gran Canaria and Tenerife,  
 441 whereas Fuerteventura and the southern parts of Gran Canaria and Tenerife are major exporters of  
 442 electricity. The high RE potential of Fuerteventura can especially well be exploited in scenario Grid+,  
 443 where the power generation provides for almost 400% of the island's demand. The surplus is used  
 444 mostly in Tenerife and Gran Canaria, substituting the more expensive offshore wind power used in  
 445 the scenarios without additional grid availability. La Gomera contributes to power supply of Tenerife  
 446 in scenario RE Base and DR-, but not in Grid+. Lowest net imports of less than 1% of the overall  
 447 demand are found for Lanzarote. El Hierro and La Palma are restricted to an island supply in scenario  
 448 RE Base and DR-, in Grid+ El Hierro produces about 18% more as it consumes, whereas La Palma  
 449 imports about 9% of its demand.

450 Owing to the high supply share of intermittent RE and limited storage, grid, and DR capacities, more  
 451 than 30% of the potential solar, wind, and wave power generation remains unused across all  
 452 scenarios. Curtailments are particularly high during spring and summer (April through August),  
 453 whereas they are negligibly during the winter (November, December, January).




**Figure 11: Power supply cost per unit of demand.**

454 Figure 11 relates the overall supply costs to the annual demand. It considers the annual depreciation  
 455 of capital expenditure as well as fixed and variable operational costs of all power generation,  
 456 transmission, storage, electric heating, hydrogen electrolysis, and DR technologies. The specific cost  
 457 of electricity generation reaches about 13 €/kWh in scenario RE Base and DR-. Owing to the shift to  
 458 cheaper technologies enabled by additional grid connections, a significant lower value of  
 459 10 €/cent/kWh is determined in scenario Grid+. Despite the differences in system operation, the  
 460 balancing costs arising from storage, grid and DR are almost identical across all sub-scenarios and  
 461 amount to about 7 €/kWh.

462 The high uncertainty of future costs of rapidly developing storage technology motivates a  
 463 quantitative sensitivity analysis with REMix. We determine that a reduction of battery storage costs  
 464 by half can lower the power generation capacity by 4%, and supply cost by 8% relative to scenario RE  
 465 Base. Nearly the same values are obtained when considering a reduction in investment costs of  
 466 hydrogen electrolysers and storage by one third, while the effects of additional grid connections in  
 467 scenario Grid+ are almost twice as high. This implies that even significant reductions in storage costs  
 468 can lower generation capacity and costs to a much lower extent than the technical possibility to  
 469 connect all islands of the archipelago. An additional model run reveals that a reduction of hydrogen  
 470 storage investment costs by 90% would enable a decrease in supply costs by 35%. With currently  
 471 available technologies, such reduction in seasonal storage costs could only be realized by using  
 472 underground cavern storage. However, owing to the volcanic activity, this technology is not suited  
 473 for the Canary Islands.


### **5.3 Long term transformation pathways**

474 Starting from the optimised power system determined with REMix, the long-term scenario pathway  
 475 focuses on the RE Base case, without engaging in additional infrastructure installation between the  
 476 islands. At the end of the transition, PV, wind, and CSP contribute 91% to the total electricity  
 477 generation (Figure 12). According to the scenario pathway, their supply share increases to 20% and  
 478 58% in 2020 and 2030, respectively. The installed capacity of RE technologies reaches 3 GW in 2030  
 479 and 12 GW in 2050.




**Figure 12: Transition of the structure of power production in the RE Base scenario for a 100% renewable target.**

480 To implement a 100% RE system, electricity also needs to increasingly compensate for fossil fuels in  
 481 the heating and transport sector. Although efficiency measures help to stabilise the heat demand, a  
 482 large portfolio of renewable sources is required to provide heat for all applications. Currently, only  
 483 2% of the officially recorded heat demand is covered by renewables, mainly by solar collectors.  
 484 Traditional biomass use is lacking official records. For low temperature heat, e.g. hot water in the  
 485 residential and commercial sector, the installation of solar collectors and ambient heat in heat  
 486 pumps are rapidly expanded in the RE Base scenario (Figure 13). Higher temperature levels for  
 487 process heat are provided by biomass and concentrating solar collectors. From 2040 on, hydrogen  
 488 and electricity replace the remaining fossil fuels. Solar thermal energy covers 15% of the heat  
 489 demand in 2030, and 26% in 2050. By then, electricity is the main heat source, covering 36% of the  
 490 demand. Both options need to be supplemented with heat storage, which can also cover for  
 491 fluctuations in power production. With additional heat supply from hydrogen (15%), ambient heat  
 492 (14%), and biomass (8%), 99% of the sectoral demand are covered by RE in 2050.



**Figure 13: Transition of heat production structure in the RE Base scenario**

493 For road transport, efficiency gains in engines, a modal shift towards busses and the shift in  
 494 propulsion technology leads to a substantial reduction of transport energy demand by 71% to 12 PJ  
 495 in 2050 (Figure 14). Biofuels can only serve as transition fuels. Hybrid, plug-in hybrids, and electric  
 496 power trains gain a significant market share by 2030, covering 12% of the transport energy demand.  
 497 Fuel cell cars become important just after 2030 especially for heavy duty vehicles. In 2050, 44% of  
 498 the transport energy demand is covered by hydrogen and 53% by electricity, leaving only 3% to  
 499 biofuels. The massive electrification of road traffic raises the electricity demand from practically zero  
 500 to 1.8 TWh in 2050.



**Figure 14: Transition of the transport sector in the RE Base scenario towards 100% renewable**

501 Across all sectors, the RE Base scenario leads to a reduction in total primary energy demand by 55%  
 502 to 86 PJ in 2050. The main energy source is solar, covering 37% of the demand, followed by wind  
 503 (31%), geothermal/ambient heat (29%), and biomass (3%). Following the transition pathway, GHG  
 504 effects of the energy system are reduced already in the near future. Power generation, which  
 505 currently accounts for half of the CO<sub>2</sub>-emissions, will remain the main source of emissions until fossil  
 506 fuels are eventually replaced by RE after 2040 (Figure 15). Decreasing demand in transport fuels also  
 507 reduces emissions from conversion, e.g. refineries. Given the increase in RE supply, CO<sub>2</sub>-emissions  
 508 are cut by 48% until 2030. In the RE Base scenario, CO<sub>2</sub> emissions are almost totally eliminated by  
 509 2050.




Figure 15: CO<sub>2</sub>-Emissions in the RE Base scenario

## 6 Discussion

510 The scenario pathway to a 100% RE supply developed in this paper relies on a back-casting approach  
 511 and provides a breakdown of long-term targets to short-term actions. It can be used as a guideline to  
 512 a carbon-free energy supply for the Canary Islands, but does not represent a prognosis of the future.  
 513 The decarbonisation scenario is limited to power, heat, and land transport, whereas aviation and  
 514 navigation are not included. Owing to the restricted RE potentials in the Canary archipelago, these  
 515 sectors will be dependent on imported hydrocarbon fuels in the future as they are today.

516 The scenario shaping methodology introduced in this work can be used for other islands or countries  
 517 as well. According to [23], the results of its application to the Canary Islands can be helpful for  
 518 designing supply systems on other islands with similar climatic, and socio-economic characteristics as  
 519 well. However, their methodology focuses on single islands, and does neither include any cross-  
 520 sectoral perspective, nor the possibility to connect different islands within an archipelago.

521 Power supply, electric heating, and synthetic hydrogen production are evaluated for the year 2050  
 522 by using a linear optimisation approach. The high temporal and spatial resolution of the applied  
 523 REMix model ensures a high quality and validity of the results compared with more aggregated  
 524 approaches. Nevertheless, the temporal resolution of REMix limits its scope to the evaluation of  
 525 hourly balancing of demand and generation. Therefore, the model does neither account for power  
 526 system stability requirements, especially the provision of operating reserve, nor does it capture  
 527 ramping limitations of thermal units. Furthermore, REMix is based on a simplified technology  
 528 representation and does not fully reflect operational restrictions. This particularly concerns thermal  
 529 power plants, but also the representation of power transmission. From this follows that our results  
 530 tend to underestimate the capacity needs for ensuring supply security at lower timescales as well as  
 531 the operational costs of power supply [68]. More detailed models need to be applied to validate and  
 532 reinforce our results. A comprehensive discussion of capabilities and restrictions of REMix can be  
 533 found in [35]. Not only the temporal, but also the spatial resolution of REMix has an impact on the  
 534 results. Maximum installable capacities and hourly output of RE technologies are likely to vary if a  
 535 higher resolution is used. Furthermore, potentials of wind turbines, CSP plants, and open space PV

536 depend to a high degree on the available areas and the area specific capacities. The input data used  
537 in this study relies on the methodologies and data presented and discussed in the cited publications.

538 The cost analysis in REMix extends beyond the usual levelised cost of electricity generation (LCOE)  
539 approach, as it also accounts for the integration costs arising from the need to balance intermittent  
540 RE generation by grid, storage and other balancing technologies [59]. To evaluate these costs, we  
541 compare them with LCOE from a predominantly fossil power supply in the Canary Islands in 2050.  
542 The detailed analysis reported in [67] shows that in a business-as-usual scenario based on same  
543 investment and fuel cost assumptions, overall LCOE reach a value of 23 €/ct/kWh. This is about 15%  
544 more than the highest value found in the REMix analysis of the present work. From this follows that  
545 fuel cost savings can more than overcompensate for the cost of additional infrastructure. A  
546 comprehensive cross-sectoral cost-benefit analysis, extending to the assessment of other  
547 externalities such as air pollutants is beyond the scope of the present study and should be addressed  
548 in future studies.

549 The data input of the analysis considers substantial future cost decreases and technology  
550 developments. Especially the consideration of improved under water cables in sub-scenario *Grid+* is  
551 important as it enables a connection of the two major islands. If this technology cannot be realised in  
552 the future, offshore wind turbines without fixed foundation are required in the subsystem formed by  
553 the islands of Tenerife and La Gomera which then substantially increases the supply costs.  
554 Furthermore, the commercialisation of wave energy is currently at an early stage and requires  
555 further enhancement and cost reduction. The same applies to the large-scale deployment of  
556 hydrogen electrolysis, storage, and re-electrification. BEV are now available from different  
557 manufacturers, but charging infrastructures still need to be provided at large scale. Technology costs  
558 assumptions have a strong impact on the results of cost-minimising linear optimisation models.  
559 Regarding the most important power generation technologies, we expect the following impact of a  
560 different cost development: Owing to the almost complete exploitation of potentials, lower or higher  
561 PV and onshore wind costs would have a very limited impact on the composition of the system, but  
562 will influence the overall supply costs. The same is true for offshore wind power, which is used only  
563 to a minor extent. The situation is different for lower or higher CSP costs as these are likely to reduce  
564 or increase the usage of PV and onshore wind.

565 The high curtailment of intermittent RE power generation indicates additional potential for balancing  
566 technologies. Additional DR or the appearance of cheaper storage technologies can enable cost  
567 reductions by avoiding the usage of the most expensive power generation technologies. The  
568 sensitivity analysis shows that a decrease in storage cost could reduce both capacity demand and  
569 costs. However, the cost-cutting potential of storage exceeds that of additional grid connections only  
570 if long-term storage is available at very low investment cost. If not stored, surplus power generation  
571 can be used for an additional electrification of heating, and transport sector as well as industry.

## 7 Conclusion

572 This paper provides a novel approach to energy scenario design. It combines a cross-sectoral energy  
573 system model in high temporal and spatial resolution with an accounting framework. This modelling  
574 framework is able to simulate a consistent pathway towards a fully renewable energy supply and can  
575 be applied globally.

576 Our modelling results highlight the importance of transmission, storage, and flexible demand in  
577 energy systems with high share of fluctuating power generation. Furthermore, they show the great  
578 potential of an intelligent linkage of power, heating, and transport sectors as well as water supply  
579 both for climate protection and cost reduction. A flexible operation of BEV charging, hydrogen  
580 electrolysis, reverse osmosis seawater desalination facilities, electric heating, CHP, and electric  
581 cooling can contribute significantly to the achievement of high RE shares across all sectors. It must be  
582 enabled by an intelligent charging infrastructure as well as thermal, hydrogen, and water storage.  
583 Their implementation is particularly important in island energy systems, where there is no or limited  
584 possibility to balance power generation fluctuations through the grid. Load shifting of BEV, heating,  
585 cooling, and desalination are found to provide cheaper storage function than the considered electric  
586 energy storage. These insights can help market actors to optimise their investment decisions and  
587 political planners to shape an appropriate regulatory framework, so that new infrastructures are  
588 designed accordingly already at their deployment.

589 With their limitations in space, biomass, and hydro power, small islands represent the most  
590 challenging environment for the implementation of a carbon-neutral energy supply. The case study  
591 region of the Canary Islands is furthermore characterised by a significant number of inhabitants and  
592 increasing tourism, but also by good solar and wind energy potentials. Our modelling results show  
593 that these potentials are sufficient for a fully renewable supply of the archipelago's power, heat, and  
594 land transport energy demands. Owing to the very limited potential of biomass, electrification of the  
595 heating and transport sector are essential elements of the system transformation. According to our  
596 results, the currently projected gas infrastructure can be completely substituted by RE technologies.  
597 Such a change, however, requires a redirection of the current and future infrastructure planning. To  
598 follow the pathway towards a carbon neutral energy supply by 2050, a broad portfolio of RE  
599 technologies needs to be developed already in an early stage of the transformation. A strong  
600 increase in the installation of wind and PV capacities is already required in the short-term; a doubling  
601 of wind capacity is necessary until 2020 and again by 2025 as well as a tripling of current PV  
602 installations by 2020 and doubling again by 2025. Besides these very mature technologies, increased  
603 efforts are required for the deployment of dispatchable CSP and PSH plants in the Canary Islands.  
604 Additionally, new technologies, including wave energy, floating offshore wind, and stationary fuel  
605 cells must be developed further to contribute to a broad power supply technology portfolio in later  
606 stages of the transformation. Apart from the gradual deployment of a new supply infrastructure, a  
607 strong increase in energy efficiency compared with current improvements is an essential  
608 precondition for the implementation of the scenario. Especially in the transport sector, large  
609 efficiency gains are achievable. However, they require a complete transformation of transport modes  
610 and technologies as well as the deployment of new infrastructures. Higher energy efficiency and  
611 reduced overall demand are crucial for keeping supply costs low, as economic RE potentials are to a  
612 very high degree exploited in our scenario. If the demand can be reduced to a lower extent, a  
613 disproportionate increase in costs will result. We determine that the realisation of sea cable  
614 connections between all islands of the Canary archipelago can enable a reduction in supply cost by  
615 15%. Consequently, additional effort is necessary to overcome application limits arising from sea  
616 depth and seabed conditions. Another key requirement to keep supply costs low is the activation of  
617 the considered DR potential. Despite the considered sector linkage, a significant share of wind and  
618 solar power generation has to be curtailed. This implies that there is huge potential for additional  
619 flexibility, including new storage options, usage of surplus generation in other sectors, or  
620 development of additional DR potentials.

621 Our modelling results can be used by energy system planners to determine RE capacity expansion  
622 pathways for the Canary Islands. Future studies are required to enhance the understanding of  
623 challenges and chances of a carbon-free energy supply. Considering different demand and RE  
624 generation profiles and performing further technology cost sensitivity analyses, the exact  
625 configuration of the supply system and the dimensioning of its elements need to be determined in  
626 future works.

## Acknowledgements

The research for this paper was partially funded by Greenpeace Spain. The authors thank Red Eléctrica de España, Endesa Energía SA as well as the Instituto Tecnológico de Canarias for their valuable input regarding the Canary Islands power system. They furthermore thank Denis Hess for his support in the REMix-EnDAT application as well as Carsten Hoyer-Klick and Benjamin Fuchs for their valuable comments on previous drafts of this paper.

## Appendix

**Table 6: Techno-economic data of the considered power generation and storage technologies, according to [56–59]. Abbreviations: PB – Power block, TES – Thermal energy storage, SF – Solar field, Stor. – Storage unit, Conv. – Converter unit**

Technology	$\eta_{\text{net}}$	Avail.		$c_{\text{invest}}$ € <sup>2</sup> /kW	$c_{\text{OMFix}}$ % of invest/a	$c_{\text{OMVar}}$ €/MWh	$t_{\text{amort}}$ a
		%	%				
Solar PV	n.a.	95%		720	1%	0	20
Wind onshore	n.a.	92%		900	4%	0	20
Wind offshore, fix	n.a.	92%		1800	5.5%	0	20
Wind offshore, floating	n.a.	92%		3000	5.5%	0	20
Wave energy	n.a.	92%		2000	5.5%	0	20
CSP	37.0% (PB) 95% (TES)	95%		970 (PB) 250 (SF) 25 (TES)	2.5%	0	25
Geothermal power	13.5%	95%		7220	4.5%	0	20
Run-of-river hydro	n.a.	95%		4000	5%	0	60
Gas turbine	46.5%	95%		400	4%	0.3	25
CCGT	66.5%	96%		700	4%	0.3	25
Biomass CHP	34% (power) 53% (heat)	98%		1100	2%	5	20
Fuel Cell CHP	27% (power) 53% (heat)	98%		1100	2%	5	20
Redox flow battery	81%	98%		100 (Stor.) 300 (Conv.)	3%	0	20
Pumped storage hydro	80%	98%		10 (Stor.) 640 (Conv.)	3%	0	60 (Stor.) 20 (Conv.)
Hydrogen storage	95%	100%		24	2%	0	30
Electrolysers	71%	100%		322	2%	4	20

<sup>2</sup> € refers to €2012

## References

- 627 [1] IPCC. Climate change 2014: synthesis Report. Contribution of working groups I, II and III to the  
628 fifth assessment report of the intergovernmental panel on climate change. Geneva, Switzerland: Core  
629 Writing Team, R.K. Pachauri and L.A. Meyer (eds.); 2014.
- 630 [2] EU-Parliament, EU-Council. Directive 2009/28/EC of the European Parliament and the Council of  
631 23 April 2009 on the promotion of the use of energy from renewable sources and amending and  
632 subsequently repealing Directives 2001/77/EC and 2003/30/EC. Official Journal of the  
633 European Union. 2009;L 140:42 ff.
- 634 [3] Monteiro Alves LM, Lopes Costa A, da Graça Carvalho M. Analysis of potential for market  
635 penetration of renewable energy technologies in peripheral islands. *Renewable Energy*. 2000;19:311-  
636 7.
- 637 [4] Riva Sanseverino E, Riva Sanseverino R, Favuzza S, Vaccaro V. Near zero energy islands in the  
638 Mediterranean: Supporting policies and local obstacles. *Energy Policy*. 2014;66:592-602.
- 639 [5] Marrero GA, Ramos-Real FJ. Electricity generation cost in isolated system: The complementarities  
640 of natural gas and renewables in the Canary Islands. *Renewable and Sustainable Energy Reviews*.  
641 2010;14:2808-18.
- 642 [6] Erdinc O, Paterakis NG, Catalão JPS. Overview of insular power systems under increasing  
643 penetration of renewable energy sources: Opportunities and challenges. *Renewable and Sustainable  
644 Energy Reviews*. 2015;52:333-46.
- 645 [7] Kuang Y, Zhang Y, Zhou B, Li C, Cao Y, Li L, et al. A review of renewable energy utilization in  
646 islands. *Renewable and Sustainable Energy Reviews*. 2016;59:504-13.
- 647 [8] Brouwer AS, van den Broek M, Zappa W, Turkenburg WC, Faaij A. Least-cost options for  
648 integrating intermittent renewables in low-carbon power systems. *Applied Energy*. 2016;161:48-74.
- 649 [9] Krajačić G, Duić N, Carvalho MdG. How to achieve a 100% RES electricity supply for Portugal?  
650 *Applied Energy*. 2011;88:508-17.
- 651 [10] Krakowski V, Assoumou E, Mazauric V, Maïzi N. Reprint of Feasible path toward 40–100%  
652 renewable energy shares for power supply in France by 2050: A prospective analysis. *Applied Energy*.  
653 2016;184:1529-50.
- 654 [11] Pfenninger S, Keirstead J. Renewables, nuclear, or fossil fuels? Scenarios for Great Britain's  
655 power system considering costs, emissions and energy security. *Applied Energy*. 2015;152:83-93.
- 656 [12] Connolly D, Lund H, Mathiesen BV, Leahy M. The first step towards a 100% renewable energy-  
657 system for Ireland. *Applied Energy*. 2011;88:502-7.
- 658 [13] Connolly D, Mathiesen BV. A technical and economic analysis of one potential pathway to a  
659 100% renewable energy system. *International Journal of Sustainable Energy Planning and  
660 Management*. 2014;1:7-28.
- 661 [14] Mathiesen BV, Lund H, Karlsson K. 100% Renewable energy systems, climate mitigation and  
662 economic growth. *Applied Energy*. 2011;88:488-501.
- 663 [15] Duić N, Lerer M, Carvalho MG. Increasing the supply of renewable energy sources in island  
664 energy systems. *International Journal of Sustainable Energy*. 2003;23:177-86.
- 665 [16] Duić N, Krajačić G, da Graça Carvalho M. RenewIslands methodology for sustainable energy and  
666 resource planning for islands. *Renewable and Sustainable Energy Reviews*. 2008;12:1032-62.
- 667 [17] Blechinger P, Cader C, Bertheau P, Huyskens H, Seguin R, Breyer C. Global analysis of the techno-  
668 economic potential of renewable energy hybrid systems on small islands. *Energy Policy*. 2016;98:674-  
669 87.
- 670 [18] Andaloro APF, Salomone R, Andaloro L, Briguglio N, Sparacia S. Alternative energy scenarios for  
671 small islands: A case study from Salina Island (Aeolian Islands, Southern Italy). *Renewable Energy*.  
672 2012;47:135-46.
- 673 [19] Katsaprakakis DA, Papadakis N, Kozirakis G, Minadakis Y, Christakis D, Kondaxakis K. Electricity  
674 supply on the island of Dia based on renewable energy sources (R.E.S.). *Applied Energy*. 2009;86:516-  
675 27.
- 676 [20] Segurado R, Costa M, Duić N, Carvalho MG. Integrated analysis of energy and water supply in  
677 islands. Case study of S. Vicente, Cape Verde. *Energy*. 2015;92, Part 3:639-48.

678 [21] Kapsali M, Kaldellis JK, Anagnostopoulos JS. Investigating the techno-economic perspectives of  
679 high wind energy production in remote vs interconnected island networks. *Applied Energy*.  
680 2016;173:238-54.

681 [22] Centeno Brito M, Lobato K, Nunes P, Serra F. Sustainable energy systems in an imaginary island.  
682 *Renewable and Sustainable Energy Reviews*. 2014;37:229-42.

683 [23] Meschede H, Holzapfel P, Kadelbach F, Hesselbach J. Classification of global island regarding the  
684 opportunity of using RES. *Applied Energy*. 2016;175:251-8.

685 [24] ISTAC. Estadísticas. Instituto Canario de Estadística, Gobierno de Canarias; 2015.

686 [25] Gobierno de Canarias. Anuario Energético de Canarias 2013. Consejería de Empleo, Industria y  
687 Turismo; 2014.

688 [26] Ministerio de Industria TeC. Planificación energética – Plan de desarrollo de la red de transporte  
689 de energía eléctrica 2015-2020, primera propuesta. 2014.

690 [27] X. Casals JDB, P. Linares Llamas, and O. López García,. *Renovables 2050. Un informe sobre el*  
691 *potencial de las energías renovables en la España peninsular. Informe del Instituto de*  
692 *Investigaciones Tecnológicas de la Universidad Pontificia de Comillas para Greenpeace2005.*

693 [28] Bueno C, Carta JA. Wind powered pumped hydro storage systems, a means of increasing the  
694 penetration of renewable energy in the Canary Islands. *Renewable and Sustainable Energy Reviews*.  
695 2006;10:312-40.

696 [29] Seven2one. Mesap. 2015.

697 [30] Seven2one. Mesap 4.11. 2010.

698 [31] Krewitt W, Simon S, Graus W, Teske S, Zervos A, Schäfer O. The 2°C scenario - A sustainable  
699 world energy perspective. *Energy Policy*. 2007;35:4969-80.

700 [32] Teske S, Muth J, Sawyer S, Pregger T, Simon S, Naegler T, et al. *Energy [R]evolution - a*  
701 *sustainable world energy outlook*. In: Alexandra Dawe, Rebecca Short, Aubrey C, editors. Amsterdam:  
702 Greenpeace International, European Renewable Energy Council (EREC), Global Wind Energy Council  
703 (GWEC), Deutsches Zentrum für Luft- und Raumfahrt (DLR); 2012.

704 [33] Gils HC. *Balancing of Intermittent Renewable Power Generation by Demand Response and*  
705 *Thermal Energy Storage: Universität Stuttgart; 2015.*

706 [34] Gils HC. *Economic potential for future demand response in Germany – Modeling approach and*  
707 *case study. Applied Energy*. 2016;162:401-15.

708 [35] Gils HC, Scholz Y, Pregger T, Luca de Tena D, Heide D. *Integrated capacity expansion and*  
709 *operation modelling for variable renewable energy based power supply in Europe. Energy*.  
710 2016;(submitted).

711 [36] IEA. *Energy balance of OECD countries (2014 edition). IEA energy statistics (Beyond 20/20)*.  
712 Paris: International Energy Agency; 2014.

713 [37] Teske S, Achternberg F, Putte JV, Pregger T, Zittel W. *Roadmap for Europe - towards a*  
714 *sustainable and independent energy supply. Greenpeace International; 2014.*

715 [38] Suganthi L, Samuel AA. *Energy models for demand forecasting—A review. Renewable and*  
716 *Sustainable Energy Reviews*. 2012;16:1223-40.

717 [39] Gobierno de Canarias. *Evolución del gasto turístico. 2015.*

718 [40] Gobierno de Canarias. *Oferta alojativa de las Islas Canarias. 2015.*

719 [41] EUROSTAT. Database. European Commission; 2015.

720 [42] IEA. *Energy Efficiency Market Report. International Energy Agency, Organisation for Economic*  
721 *Co-operation and Development; 2015.*

722 [43] Teske S, Zervos A, Lins C, Josche M, Krewitt W, Pregger T, et al. *Energy [R]evolution - a*  
723 *sustainable world energy outlook*. Amsterdam: Greenpeace International, European Renewable  
724 Energy Council (EREC), Deutsches Zentrum für Luft- und Raumfahrt (DLR), ecofys; 2010.

725 [44] Kermeli K, Graus WJ, Worrell E. *Energy efficiency improvement potentials and a low energy*  
726 *demand scenario for the global industrial sector. Energy Efficiency*. 2014;7:987-1011.

727 [45] Instituto Tecnológico de Canarias. *Mapa Solar de Canarias. 2011.*

728 [46] Schallenberg-Rodríguez J. *Photovoltaic techno-economical potential on roofs in regions and*  
729 *islands: The case of the Canary Islands. Methodological review and methodology proposal.*  
730 *Renewable and Sustainable Energy Reviews*. 2013;20:219-39.

731 [47] Schallenberg-Rodríguez J, Notario-del Pino J. Evaluation of on-shore wind techno-economical  
732 potential in regions and islands. *Applied Energy*. 2014;124:117-29.  
733 [48] Instituto Tecnológico de Canarias. Mapa Eólica de Canarias. 2011.  
734 [49] Martín Mederos AC, Medina Padrón JF, Feijóo Lorenzo AE. An offshore wind atlas for the Canary  
735 Islands. *Renewable and Sustainable Energy Reviews*. 2011;15:612-20.  
736 [50] IDAE. Evaluación del potencial de la energía geotérmica. Instituto para la Diversificación y Ahorro  
737 de Energía; 2011.  
738 [51] IDAE. Evaluación del potencial de la energía de la biomasa. Instituto para la Diversificación y  
739 Ahorro de Energía; 2011.  
740 [52] Santamarta JC, Jarabo F, Rodríguez-Martín J, Arraiza MP, López JV. Analysis and Potential of Use  
741 of Biomass Energy in Canary Islands, Spain. *IERI Procedia*. 2014;8:136-41.  
742 [53] IDAE. Evaluación del potencial de la energía de las olas. Instituto para la Diversificación y Ahorro  
743 de Energía; 2011.  
744 [54] Gonçalves M, Martinho P, Guedes Soares C. Assessment of wave energy in the Canary Islands.  
745 *Renewable Energy*. 2014;68:774-84.  
746 [55] Sierra JP, González-Marco D, Sospedra J, Gironella X, Mösso C, Sánchez-Arcilla A. Wave energy  
747 resource assessment in Lanzarote (Spain). *Renewable Energy*. 2013;55:480-9.  
748 [56] Gobierno de Canarias. Planes hidrológicos de las Islas Canarias. 2015.  
749 [57] Pietzcker RC, Stetter D, Manger S, Luderer G. Using the sun to decarbonize the power sector:  
750 The economic potential of photovoltaics and concentrating solar power. *Applied Energy*.  
751 2014;135:704-20.  
752 [58] Stetter D. Enhancement of the REMix energy system model: Global renewable energy potentials,  
753 optimized power plant siting and scenario validation: Universität Stuttgart; 2014.  
754 [59] Scholz Y, Gils HC, Pietzcker R. Application of a high-detail energy system model to derive power  
755 sector characteristics at high wind and solar shares. *Energy Economics*. 2016.  
756 [60] Trieb F, Schillings C, Pregger T, O'Sullivan M. Solar electricity imports from the Middle East and  
757 North Africa to Europe. *Energy Policy*. 2012;42:341-53.  
758 [61] Suárez BP. personal communication. Instituto Tecnológico de Canarias 2015.  
759 [62] Moser M. Combined electricity and water production based on solar energy: University of  
760 Stuttgart; 2015.  
761 [63] Schallenberg-Rodríguez J, Veza JM, Blanco-Marigorta A. Energy efficiency and desalination in the  
762 Canary Islands. *Renewable and Sustainable Energy Reviews*. 2014;40:741-8.  
763 [64] Sadhwani JJ, Veza JM. Desalination and energy consumption in Canary Islands. *Desalination*.  
764 2008;221:143-50.  
765 [65] Gils HC. Assessment of the theoretical demand response potential in Europe. *Energy*. 2014;67:1-  
766 18.  
767 [66] Enerdata Research Service. Odyssee database on energy efficiency data and indicators. 2012.  
768 [67] de Otto S, Bevaqua M, Ferrán F, Teske S, Simon S, Gils HC. Energy [R]evolution for the Canary  
769 Islands - Energy design for sustainable islands. In: García del Vado C, editor.: Greenpeace España;  
770 2015.  
771 [68] Deane JP, Drayton G, Ó Gallachóir BP. The impact of sub-hourly modelling in power systems with  
772 significant levels of renewable generation. *Applied Energy*. 2014;113:152-8.  
773