Joule

Perspective

Techno-Economic Assessment of Soiling Losses and Mitigation Strategies for Solar Power Generation

Klemens Ilse,^{1,2,3,4,*} Leonardo Micheli,⁵ Benjamin W. Figgis,⁶ Katja Lange,^{1,2} David Daßler,^{1,2} Hamed Hanifi,^{1,2} Fabian Wolfertstetter,⁷ Volker Naumann,^{1,2} Christian Hagendorf,^{1,2} Ralph Gottschalg,^{1,2,3} and Jörg Bagdahn³

Soiling consists of the deposition of contaminants onto photovoltaic (PV) modules or mirrors and tubes of concentrated solar power systems (CSPs). It often results in a drastic reduction of power generation, which potentially renders an installation economically unviable and therefore must be mitigated. On the other hand, the corresponding costs for cleaning can significantly increase the price of energy generated. In this work, the importance of soiling is assessed for the global PV and CSP key markets. Even in optimized cleaning scenarios, soiling reduces the current global solar power production by at least 3%–4%, with at least 3–5 billion \in annual revenue losses, which could rise to 4%–7%, and more than 4–7 billion \in losses, in 2023. Therefore, taking into account the underlying physics of natural soiling processes and the regional cleaning costs, a techno-economic assessment of current and proposed soiling mitigation strategies such as innovative coating materials is presented. Accordingly, the research and development needs and challenges in addressing soiling are discussed.

INTRODUCTION

Soiling can easily cause more than 1% power loss per day¹⁻⁴ and is a site-specific phenomenon, strongly influenced by local climatic conditions.^{1,5-11} The predominant type of contamination could change considerably depending on the location: mineral dust deposits¹ (Figure 1A), bird droppings (Figure 1B), biofilms of bacteria, algae, lichen, mosses, or fungi¹²⁻¹⁴ (Figure 1C), plant debris or pollen¹⁵ (Figure 1D), engine exhausts or industry emissions (Figure 1E), and agricultural emissions such as feed dusts (Figure 1F).

For PV modules, soiling on the front glass mainly results in optical losses due to light absorption or backward scattering,^{2,16} depending on the area shaded by soiling particles and also on the dust compositions and particle size distributions.^{2,8,16,17} Compared to PV, soiling-induced losses are 8–14 times greater for CSP because most of the forward scattered light, which could still generate electricity in PV, does not hit the CSP receiver due to limited collector acceptance angles. Similar applies to concentrator photovoltaics (CPVs), which also use lenses or mirrors. However, as CSP only accounts for about 1.1% of global installed solar power capacity, and CPV being less than 0.1%, the focus of this study is set on conventional PV.^{18–20}

The physics of dust deposition and adhesion are complex due to the many influencing factors, ranging from weather, site, and system specifications to surface

Context & Scale

The light-collecting surfaces of solar power systems cover areas of more than 3,000 km² worldwide, with PV modules accounting for the majority. An often-neglected problem is the contamination of these surfaces, so-called "soiling," which leads to significantly reduced energy yields, especially in highinsolation arid and semi-arid climates. Indeed, an inadequate soiling mitigation strategy in high solar-potential and soiling-prone locations such as China, India, or the Middle East can cancel out in few weeks the impressive progress in solar cell and CSP efficiency made in recent decades.

CelPress

Currently, there is no onesolution-fits-all to the problem of soiling due to its site-specific and seasonal variability, differences in local energy costs, and the availability and costs of resources required for cleaning, such as water or labor. Indeed, frequent cleaning can increase the energy generation costs and water consumption dramatically, leading to a need for water-less and inexpensive soiling mitigation technologies. Our analysis

Joule

nano-characteristics as well as their time-variability (e.g., diurnal or seasonal weather changes).¹ Airborne dust concentration is considered the major determinant of soiling, ^{1,6,7,21} together with rain frequency, as rain is quite effective at cleaning soiled surfaces if sufficiently abundant.^{1,6,22} On the other hand, rain can also cause negative effects, e.g., by wet deposition of aerosol particles that have been washed out of the atmosphere.²³ Wind speed is also an important parameter, as it influences the particle deposition mechanisms and rates the balance between deposition and resuspension.^{24–26} Tilt angle of the PV modules and CSP mirrors should be considered since soiling rates are greater on flatter surfaces.² Relative humidity and dew strongly enhance dust adhesion to surfaces through capillary forces, particle caking, and cementation.^{1,17,27,28} These moisture-related adhesion mechanisms are considered important, even in deserts: radiative cooling of the glass surfaces at night allows surfaces to cool below the ambient air temperature. They frequently reach the dew point, and thus, dew precipitates on the collector surfaces.^{1,27}

On top of reversible optical losses, soiling can cause permanent degradation of PV modules and mirror materials. In cases of omitted cleaning, cemented dust layers, lichens, and fungi can become practically irremovable, whereas harsh cleaning can lead to the scratching or abrasion of typical anti-reflective coatings (ARCs) or glass corrosion.^{13,29,30} In addition, mechanical loads during cleaning or thermal shocks when a hot element is cleaned with cold water may lead to breakage of solar cells and glasses or expansion of micro cracks. Further, potential induced degradation (PID) in PV can be enhanced by soiling,^{31,32} and partial shading due to non-uniform soiling can lead to the formation of hot spots. In CSP, increased dust loads can lead to accelerated degradation of receivers by particle melting, failure of bearings, ball joints, and others.

However, within this study, only the optical and corresponding yield losses due to soiling are considered for the investigation of the global impact of soiling. Currently, cleaning is the state-of-the-art to tackle soiling. Cleaning economics also determine the economic viability of other mitigation technologies. Therefore, the technoeconomic feasibility of potential technologies is investigated based on an evaluation of their efficiency in soiling loss reduction and potential costs. The most promising available strategies are thus identified and recommendations provided for further research.

IMPACT ON GLOBAL SOLAR POWER PRODUCTION AND ENERGY COSTS

In order to estimate the global impact and cost of soiling, the optimum between cleaning costs and revenue losses due to soiling between cleaning events was determined for the twenty top PV markets (about 90% of global installed PV capacity in 2018³³) and the global CSP market. Accordingly, an extensive dataset was compiled from literature and interviews with stakeholders, including regional soiling rates (Figure 2B and Tables S1–S3), local cleaning costs (Figure 2C and Table S1), and simulated local energy yields (Figure 2D and Table S4). From these, the optimum number of cleaning cycles per year was calculated for each country (Figure 2E). The calculations were performed considering the reported installed capacity³³ and regional feed-in-tariffs³⁴ from 2017 to 2018, as well as a medium growth scenario and an average electricity price of 0.03€/kWh for 2023. In addition, the total costs of soiling being the sum of optimized annual cleaning costs and the remaining revenue losses were determined (Figure 2F). Further details of the methodology are provided in the Experimental Procedures and the Supplemental Information.

indicates that in addition to optimized cleaning plans, automated cleaning machines, anti-soiling coatings, tracking system modifications, PV module design, improved soiling monitoring, and site adaption can be economically feasible and effective solutions to reduce the negative impact of soiling. Other technologies like electrodynamic screens or dew mitigation need further research and development to improve functionality and become economically relevant for large-scale application.

¹Fraunhofer Center for Silicon Photovoltaics CSP, 06120 Halle (Saale), Germany

²Fraunhofer Institute for Microstructure of Materials and Systems IMWS, 06120 Halle (Saale), Germany

³Anhalt University of Applied Sciences, Faculty EMW, Koethen (Anhalt), Germany

⁴Institute of Physics, Martin Luther University Halle-Wittenberg, 06120 Halle (Saale), Germany

⁵Centre for Advanced Studies on Energy and Environment (CEAEMA), University of Jaén, 23071 Jaén, Spain

⁶Qatar Environment and Energy Research Institute (QEERI), HBKU, Doha, Qatar

⁷German Aerospace Center (DLR), Institute of Solar Research, Plataforma Solar de Almería, 04200 Tabernas, Spain

*Correspondence: klemens.ilse@csp.fraunhofer.de https://doi.org/10.1016/j.joule.2019.08.019

CellPress

Joule

CellPress



Figure 1. Examples of Soiling

Overview of different soiling types with exemplary photographs of soiling by (A) mineral dust in a desert area, (B) bird droppings, (C) algae, lichen, mosses or fungi and (D) pollen in wet and moderate climates, (E) engine exhaust from an industrial area, and (F) agricultural emissions.

According to the data presented in Figure 2, soiling is estimated to have reduced global solar power production by at least 3%-4% in 2018, causing global revenue losses of at least 3-5 billion \in . This conservative estimate does not consider additional costs of non-optimized PV cleaning schedules (e.g., in residential application) and cleaning rooftop installations (3-8 times costlier than cleaning ground-mounted PV), which accounted for about 29% of global installations in 2018.³³ This assumption is less pronounced for CSP, as this technology is only profitable in large plants where cleaning is typically performed in a more cost-optimized manner. Higher incentives of power purchase agreements that were contracted earlier than 2018 were not taken into consideration. Such projects tended to have higher prices for generated electricity, which would increase the optimum cleaning frequency and the related cleaning expenses. Secondary effects such as increases in loan rates due to the uncertainty of yield forecasts because of the unpredictability of soiling could also have a financial impact but were not evaluated here.

Based on the assumptions made, global soiling losses could rise significantly to 4%–7% of annual power production, causing more than 4–7 billion \in economic losses by 2023. This development is mainly driven by an increased deployment of PV in high insolation and also in highly soiling-affected regions such as China and India, as well as the mentioned low predicted electricity price, which reduces the incentive for cleaning.^{35,36} Additional factors that increase the impact of soiling are rising PV module efficiencies and a predicted increasing share of rooftop installations in PV (from about 29% in 2018 up to about 35% in 2023³³). They have not yet been considered in the calculations. Other factors such as improved air quality in some parts of the world^{37–41} could reduce anthropogenic sources of soiling, although air-quality policies typically operate over long time scales. On the other hand, the increase in temperature and the changes associated with climate change might cause a rise in the global soil aridity⁴² and the risk of droughts⁴³ and wildfires, worsening PV and CSP soiling because of the higher concentration of aerosols and the more irregular precipitation patterns.

Joule

CellPress



Figure 2. Impact of Soiling on Solar Power Generation

(A) PV capacity installed by 2018 and medium estimate for 2023, sorted by country for the top 22, and global CSP capacity.

(B) Corresponding soiling rates reported in literature; see Tables S2 and S3.

(C) Reported cleaning costs per cleaning and square meter.

(D) Typical energy yield in kWh/kW $_{\rm p}$ for representative locations, see Table S4.

(E) Calculated range of optimal number of yearly cleaning cycles (bars) and actual range of typical yearly cleaning cycles reported in literature (blue lines, see Model Validation). The arrow indicates that for CSP, the numbers are out of range and (up to 85 in 2018 and 55 in 2023).

(F) Minimum expected financial losses due to soiling calculated from optimum cleaning cycles.

TECHNICAL EVALUATION OF SOILING MITIGATION TECHNOLOGIES

The previous section described the severity of soiling across the solar-energy industry. Here, soiling mitigation and cleaning strategies as reported in various studies and reviews^{2,44–51} are re-assessed to gain new insights into physical constraints and technology developments. New innovative approaches are suggested and evaluated.

Joule

CellPress



Figure 3. Overview of Different Cleaning Technologies Sorted by Category: Manual, Semi-automatic (Including Truck-Mounted Solutions and Portable Robots), and Fully Automatic

Cleaning

So far, no passive anti-soiling technology (e.g., surface coatings) completely eliminates the need for cleaning. Furthermore, there is not a universally recommended cleaning method, as the economics and effectiveness change with local conditions, available resources, and cleaning frequencies. In general, cleaning methods can be categorized into manual, semi-automatic, and fully automatic (Figure 3). A further distinction can be made between dry cleaning technologies on the one hand that are currently only available for PV and not CSP and are mostly applied in regions with water scarcity such as desert environments, and wet cleaning technologies on the other hand, that are generally preferred due to their increased cleaning efficiency and lower damage potential.¹³ Despite this, the fully autonomous cleaning market, which represents only 0.13 % of the current global solar capacity, is expected to grow from about 1.9 GW today to 6.1 GW in 2022,⁵² thanks to the recent developments of dry, fully automated robots, which can be already integrated into the plant design.

There are many factors influencing the decision on optimal cleaning technology, including soiling type and deposition rates, water availability, accessibility of the site, and system configuration (e.g., tracking versus fixed tilt angle, roof versus ground mounted) as well as labor cost, equipment required, and feed-in contract conditions. Efforts are being made to also identify optimal cleaning schedule based on soiling rate detection and weather as well as dust forecasts.

Anti-soiling Coatings

Anti-soiling coatings (ASCs), applied to the front glass of PV modules or CSP mirrors, aim to reduce soiling and the demand for cleaning. Ideally, ASCs are highly transparent, anti-reflective, durable, non-toxic, applicable at industrial scale, low cost, and, of course, self-cleaning and are considered as a "holy grail" by the soiling community.²

Five dry and wet soiling mechanisms (Figure 4A), especially important for ASC performance in arid regions, have been identified through outdoor and laboratory testing.^{1,17,24,27,53–55} They are (1) rebound (particles bouncing off the surface upon impact), (2) resuspension (delayed removal of particles by wind), (3) caking (rearrangement and compaction of particles during dew events), (4) cementation

Joule

CellPress



Figure 4. Schematic Illustration of Soiling Mitigation Technologies

(A) Important soiling mechanisms which could be addressed by anti-soiling coatings (ASCs).

(B) Single-axis tracking and optimization of night stowing position.

(C) Working principle of EDS (standing wave version).

(D) Dew mitigation by low- $\boldsymbol{\epsilon}$ coatings and active and passive heating.

(E) PV module design approaches for soiling loss reduction: the red overlay indicates lost cell strings dew to soiling. (F) Site adaption.

(formation of chemical and/or solid bridges between particles and surfaces after dew cycles), and (5) water cleaning (particles washed off by rain or strong dew). To reduce soiling, rebound, resuspension and water cleaning should be enhanced, cementation should be avoided, and the optical loss (projected area) of caked particles should be minimized by "herding" dust into agglomerates via coating hydrophobicity.^{28,56} However, limitations arising from physical phenomena must be considered:

- Location: factors affecting soiling rate and coating performance can change dramatically with location, as well as with diurnal and seasonal variation of weather conditions. Consequently, coatings need to be tailored to specific site conditions.
- Particle adhesion physics: dust particles smaller than 10–20 µm diameter are essentially irremovable by wind because they are immersed in a thin viscous part of the boundary layer, which attenuates flow velocity and turbulence.^{1,55} Furthermore, when dew occurs, particles typically become more tightly adhered to the surface.²⁷ The particle size distribution of surface soiling differs by location, with a volume fraction of particles < 20 µm generally in the range of

Joule



35%–90%.^{1,26} Consequently, small particles remain stuck to the PV or mirror surfaces and, over time, comprise an increasing fraction of the soiling layer and optical losses.

• Durability: coating performance tends to degrade over time due to abrasion (by cleaning or sand storms),^{13,29} particle settlement and cementation,¹⁷ UV irradiation, temperature cycles, or even by rain or condensed water.^{57,58} There are two components to this degradation: a permanent degradation due to the physical damage or removal of the ASC itself and a temporal degradation due to the contamination of its outermost surface by the environmental matter, which obstructs its anti-soiling properties. Indeed, this latter type can also have permanent effects if not properly and timely addressed.^{17,30} The durability and long-term performance of coatings are currently difficult to predict, and the community has been working to identify standard methodologies to test them in advance, e.g. IEC 62788-7-3 or VDI 3956-1.

ASCs have seen limited market deployment, as they do not eliminate the need for cleaning but offer longer periods between cleanings. Nevertheless, the attraction of a passive anti-soiling solution is great, so that development continues, with many promising approaches.^{2–4} Soiling rate reductions of more than 80% have been reported from outdoor exposure studies; however, over longer periods, average anti-soiling performances are typically much lower (e.g., 20%–50%) and could even be worse than uncoated glasses depending on coating type, local climatic conditions, and status of degradation.^{28,59–73}

Tilt Angle and Solar Trackers

Field studies consistently show that soiling rates significantly decrease at steeper surface tilt angles.^{2,47,74} In addition, new insights indicate that, for several locations at least, soiling could be similar or even greater during the night than during the day,^{1,75} suggesting soiling mitigation by vertical or inverted overnight stowing⁷⁶ (see Figure 4B). Experiments conducted on glass coupons in Doha, Qatar, showed an average soiling loss reduction of 41% for vertical stowing and of 50% for inverted stowing during the night.⁷⁷ In addition, about 60% reduction in soiling loss was reported in India for PV modules inverted upside down during non-sunshine hours,⁷⁸ and more than 98% for non-tracked vertical mounted bifacial modules.⁷⁹

An analysis of the top 13 PV solar tracking companies indicated that a 90° or 180° stowing technique could not be currently applied, as the tilt angle range for typical tracker designs are either $\pm 45^{\circ}$ or $\pm 60^{\circ}$. With the solar tracker market share of utility-scale PV plants estimated to rise from about 20% in 2016 to 40% in 2020,³⁵ the concept of extending the tracker tilt range for night stowing appears a potential cost-effective soiling mitigation strategy. In contrast, the grand majority of CSP heliostats do have the inverted stow option, and parabolic troughs are typically stored in -15° toward the ground. However, some heliostat concepts do not allow inverted stow positions, and changing its design was considered not convenient for one example due to increased construction cost that was estimated not to be compensated by the reduced cleaning cost.⁸⁰ Accordingly, the technical feasibility of tracker adaption must be examined individually. Nevertheless, steep stowing positions of traditional PV tracking systems during the night have already been reported to decrease soiling by more than 30%.⁸¹

Joule

CellPress

Heating of Surfaces Preventing Water Condensation

Dew has been identified as a crucial factor in soiling in many places, both for PV and CSP, by increasing cementation, decreasing particle rebound and causing distinct soiling patterns.^{1,27,53} Condensation typically peaks before dawn, when the relative humidity is high, and PV modules are colder than the ambient air temperature because of their infrared radiative emission to the sky (so-called radiative cooling). PV modules are reported to cool significantly below ambient temperature so that the dew point temperature is reached frequently, especially in clear sky conditions.^{1,53} Additionally, condensation may also occur at temperatures above the dew point due to capillary and hygroscopic condensation.^{27,53} Soiling rates are reported to be considerably higher on days with dew occurrence as compared to dry days.⁸² Accordingly, new approaches were proposed for soiling mitigation by preventing condensation through active and passive surface heating^{17,27} (see Figure 4D). This includes heat generation by controlled current supply to solar cells, adapted application of photovoltaic thermal hybrid solar collectors⁸³ or using latent heat from phase-change materials (PCM), typically proposed for PV cooling during the day.⁸⁴ In addition, low-emissive (low- ε) coatings could significantly reduce the radiative cooling and therefore the occurrence of dew. Active heating with relatively high power indicated up to 65% soiling reduction, ^{17,27} but so far no results, models. or practical conclusion on the economic feasibility of heating approaches to reduce soiling exist. However, in combination with positive effects of PV module cooling during the day (higher energy yield, reduced PV module degradation due to lower daily temperature difference), heating modules at night might offer potential for soiling mitigation in situations with high cleaning and maintenance costs (e.g., remote locations, street lighting, and building-integrated PV) in arid environments.

Electrodynamic Screens

Transparent electrodynamic screens⁴⁷ (EDSs), also called electrodynamic dust shields⁸⁵ or cleaning systems,^{86–88} repel dust particles by creating a time-varying (dynamic) electric field over a surface.² The fields are often generated by interdigitated electrodes embedded in a protective film, supplied with alternating high voltages (Figure 4C). EDSs have been successfully demonstrated in the lab and are often proposed as an anti-soiling strategy for PV and CSP. However, they have proved difficult to translate to the field, where harsh conditions interfere with the electronic systems, and dust becomes cemented to the surface by moisture.^{2,45,47,85} Some common issues have been reported, including reduced effectiveness in cases of high relative humidity,^{2,89} long particle duration on the surface,^{2,85} and low surface tilt angle.⁸⁹ A recently launched commercial device reported 32% soiling rate reduction in Saudi Arabia,⁸⁷ but large-scale implementation has not occurred yet due to its relatively high cost of around 30 €/m² (PV module prices are actually in the range of 30–90 €/m²). There are attempts to mass-produce EDS systems to lower their cost. However, the cost reduction potential and effectiveness in a variety of weather conditions and durability still need to be demonstrated for market adoption. Therefore, in the near future, EDSs are likely to be limited to applications where high system costs are acceptable.

PV Module Design

PV module design and materials can themselves be tailored to reduce impacts of non-uniform soiling patterns. Examples are use of half-sized PV cells, configuration of cell strings and bypass diodes, and frameless modules to avoid dirt collection at edges. Partial shading, due to dust accumulating preferentially on one part of a PV module, can degrade power output significantly more than the same amount of dust spread uniformly. Indeed, shading only 50% of a single solar cell can trigger the bypass diode of this string (see schematic in Figure 4E), which could lower the power

Joule

production of a typical 3-string module by one third. Considering that soiling generally accumulates on the bottom frame, a dense strip of dust covering the bottom row of cells could theoretically cause complete power loss if the module was unfavorably oriented. In contrast, for modules using half-sized PV cells, the risk of this situation can be reduced by parallel sub-strings of cells.^{90,91} Half-cell modules could have up to 65% higher power than an equivalently shaded full-cell module, but this also strongly depends on the cell interconnection layout, the shading pattern, and module orientation. Further, under partial shading conditions, half-cell modules could have a lower temperature due to changed reverse-biased heat dissipation.⁹² Actually, there are already commercial PV modules with favorable module design available in the market. With lower electrical losses and the higher optical gains, the half-cell modules are expected to show almost similar or even lower costs in production per Watt peak compared to full-size modules.⁹³

Site Selection, Adaption, and Monitoring

The possibility of soiling mitigation through selection and modification of the plant site has received little attention from PV researchers. However, lessons can be drawn from experience with CSP systems,⁴⁵ which are more strongly affected by soiling than PV. First, soiling (daily loss rate, rain frequency, and dust characteristics) should be analyzed at each potential site during resource assessment measurement campaigns using full-size PV modules or CSP soiling measurement devices at their intended tilt or tracking pattern and orientation. It is not yet possible to accurately predict soiling only from climate information, although some studies could show underlying principles of soiling dependencies on other weather parameters.^{1,10,24,75,94-96} In addition, soiling rates can vary dramatically for sites only 5-10 km apart or even within the same site.⁹⁷ The closer a site is to a dust generation source, the greater is its soiling risk.¹ Industrial dust sources such as cement plants, agriculture and livestock farms, and dirt roads or high traffic roads can be avoided by site selection. If such sources are unavoidable, their impact can be mitigated by design and layout of the solar plant to facilitate cleaning, e.g., choosing row spacing and length to allow efficient use of truck-mounted systems or automated cleaning machines. In addition, preventive measures can reduce the impact of fugitive local dust sources e.g., by water spray, vegetation, paved roads, dust barriers, or increased height of installation (see Figure 4F).⁴⁵ Chemical soil stabilizers have been used in some US PV plants and reduced dust emission by orders of magnitude.⁹⁸ Wind and dust barriers have the potential to reduce soiling as shown by wind tunnel and FEM dust transport simulations,^{99,100} but their effectiveness has to be proven in operating environments⁴⁵ and might need to be tailored to the specific site, as strong wind could both worsen or ameliorate soiling.²⁶

Monitoring is an essential soiling mitigation tool, as it helps to detect extreme soiling conditions and to adapt the cleaning schedule depending on the interannual variability of the climatic conditions, or to other exceptional soiling events, such as road or building works. For large PV systems, ideally also soiling non-uniformity is mapped to identify sections that are economically worth cleaning. The current IEC 61724-1 standard¹⁰¹ recommends to monitor soiling where the expected annual losses are higher than 2% with at least two soiling sensors for PV sites of more than 5 MW. There are numerous soling sensor concepts, including two-sensor systems (at PV-cell or module level), where one of the sensors is cleaned regularly (manually or automatically), and more recent developments toward maintenance-free sensors.^{50,102–106} In CSP, it is recommended to monitor soiling on a daily basis by handheld devices¹⁰⁷ that are operated

CellPress

Joule

CellPress

Table 1. Economics of Soiling Mitigation

Assumed Reduction in Soiling Rate	Reduction of Optimum Number of Annual Cleaning Cycles	Remaining Cumulative Yield Loss	Allowed Costs for Mitigation Technology to Achieve Positive NPV
-100%	-100%	0%	5.00–7.90 €/m² (average) 1.00–18.70 €/m² (min-max)
-80%	-55%	45%	2.50–4.20 €/m² (average) 0.60–10.40 €/m² (min-max)
-50%	-29%	71%	1.30–2.20 €/m² (average) 0.30–5.50 €/m² (min-max)
-20 %	-11%	89%	0.50–0.80 €/m² (average) 0.10–2.00 €/m² (min-max)

Estimate of maximum allowed technology costs to achieve a positive net present value (NPV), calculated for different theoretical soiling rate reductions and assuming utility-scale PV plants, optimum cleaning cycles, power purchase prices of 0.03 €/kWh, ³⁶ and a 10-year payback period for technology investment at 5% discount rate.¹¹³

by solar field technicians. One of the challenges here is to select the minimal number of measurement points to sufficiently predict the average solar field cleanliness.^{108,109} A tendency to make soiling measurements less labor intensive is also predominant in CSP soiling sensor development.¹⁰⁷

A qualitative survey of the soiling distribution at a plant can also be conducted through visual terrestrial or aerial (drone and satellites) inspection of the field or by advanced solar field performance analysis (e.g., monitoring on module-level), with new methods being continuously developed.^{50,110–112}

Cost Estimates for Soiling Mitigation Technologies

From the data presented in Impact on Global Solar Power Production and Energy Costs, rough estimates for a positive net present value (NPV), at which soiling mitigation technologies become economically feasible, were calculated assuming different efficiencies for the reduction of soiling rates, see Table 1.

The values vary greatly between different countries and site conditions, as indicated by the range of global minima and maxima. Economic benefits from soiling mitigation leading to reduced numbers of cleaning cycles could easily increase with higher cleaning costs (e.g., rooftop installations and remote locations) or in areas with extreme soiling.

The provided estimates can be compared with our assumptions for soiling rate reduction potential and current costs of the different technologies; see Table 2. The automated cleaning systems, ASCs, optimized PV module design, and tracker solution are assumed to reach a feasible cost range at utility scale. In contrast, electrodynamic screens and heating solutions appear too expensive, or the technology is not mature enough.

CONCLUSIONS AND RECOMMENDATIONS

Due to its large impact on the maintenance and economics of solar-energy plants, there is growing interest in soiling mitigation in the solar power industry and research community, with the publication rate on the topic increasing exponentially since 2008.^{3,4} However, the amount of research is small compared to other fields of solar technology such as PV cell development or CSP plant design. To place these topics into perspective, the increase in crystalline PV cell efficiencies achieved

Joule

CellPress

Mitigation Technology	Potential Optimum Reduction of Soiling Rates	Costs	Potential Limitations	Most Reasonable Application Scenario
Fully automated cleaning	>95%	2.4–8.2 €/m ^{2 49,114}	integration in plant design	PV utility scale, ground mounted
 Anti-soiling coatings Applied by glass manufacturer Retro-fit 	<<80% (literature review) <20%–50% (authors estimate) 32% reported for commercial coating ⁷²	<2 €/m ²	performance dependent on location and season, degradation by cleaning and environmental stresses	utility scale, residential, ground- mounted and rooftop, BiPV, CSP + extra benefit from AR property
Tracking	<40%-60%	n.a.	integration in plant planning, additional costs	utility scale, ground mounted, state of the art in CSP
Electrodynamic screen/shield (EDS)	<<98% (laboratory) 32% ⁸⁷ reported for 2-year study in Saudi Arabia	<30 €/m ²	expensive, large-scale application needs to be proven	BiPV, island systems, street lighting, rooftop, CSP
Heating • PCM • Active cell heating • PVT	<20%-60%	<80 €/m² (PCM) n.a.	expensive, large-scale application needs to be proven	BiPV, island systems, street lighting, rooftop installations + extra benefit from cooling during day for PCM + PVT
Optimized PV module design and orientation	<65%	≤0 €/W _p	integration into mass production	utility scale, rooftop installations
Site adaption	unknown, site specific	n.a.	little experience, research needed	utility scale PV and CSP

Table 2. Soiling Reduction Potential and Costs for Selected Soiling Mitigation Technologies

over the past two decades (about 10% relative) will be eliminated by a few weeks of soiling in arid regions. Yet the soiling problem is far from solved, although there are multiple mitigation approaches.

Based on a techno-economic assessment, we identified automated cleaning machines, ASCs, tracker modification with inverted stowing, and optimized PV module designs as potentially applicable on a large scale in the medium term. For these technologies, the reduced soiling rates can lead to sufficiently lower cleaning expenses, so that the estimated investment costs become reasonable, especially in areas with high soiling rates. However, the economic conditions are very challenging, as, e.g., a soiling rate reduction of 50% might only allow additional costs in the range of $2 \in /m^2$ for PV. Accordingly, earlier-stage technologies like EDS and night-time heating are currently too expensive and insufficiently validated under field conditions, but their development is far from exhausted and should be continued. In addition, more research is still needed on the location-dependent effectiveness of all suggested technologies, their possible impacts on the environment and on the long-term reliability of the PV modules or CSP mirrors and also operating practices to assure effective and secure use of the technologies.

Together with the technological approaches, soiling mitigation can start at the site selection and plant design stage. Studies on this aspect are particularly lacking, suggesting that more research is needed on soiling monitoring (including resource assessment campaigns), soiling modeling, and integration into meteorological models.

In addition, there is a particular need for passive anti-soiling solutions for difficult to reach locations, such as rooftops and remote sites, which would also allow higher investment costs. Here, ASCs can be a useful complement to an active cleaning program by extending the period between cleanings. Innovative materials and new concepts continue to be developed, targeting new functionalities such as self-healing, promotion of condensation run-off, or retro-fit application. Key remaining challenges include durability and effectiveness in different climate conditions.

Joule

CellPress

EXPERIMENTAL PROCEDURES

Estimation of Global Soiling Impact

Since soiling rates vary significantly with location, technology, site specifics, season and time of the day, a statistical analysis of in excess of 100 publications reporting soiling rates for PV modules and CSP plants for different regions of the world was used to estimate regional losses and their variability, see Figure 2B. A detailed overview of the literature results is presented in the Supplemental Information; see Tables S1–S3. Only data from outdoor exposure experiments performed at typical tilt angles were considered because soiling increases dramatically for low tilt angles. From the dataset of each country, the median value was chosen for calculation. For countries with no data available from literature, estimates from soiling rates from nearby countries were used.

In comparison to soiling rate studies, there are only a few scientific reports on common cleaning economics and costs with regard to PV soiling.^{9,22,51,115–126} The outcomes of these studies are difficult to compare, as they mostly report on soiling economics for a particular site (sometimes without optimization), use complex model approaches that are not easy to reproduce or are based on limited or outdated data. Therefore, information on cleaning costs has been compiled from industry partners and stakeholders, indicating huge differences between the different countries and different sites and plant sizes (see Figure 2C). For the calculations, both minimum and maximum values for utility plants were used. In the case that no reliable data was available, cleanings costs were estimated based on costs in countries with comparable economic development and labor conditions.

The specific yield for PV systems was simulated with the project design software PV*SOL premium 2018 for a 67 kW_p PV system with 200 PV modules from Canadian Solar Inc. (CS6U-335P) and an inverter from SMA (Sunny Tripower 8000TL-20). From this, the energy yield was determined at fixed, optimum tilt without soiling losses for one year for several locations for each country (see Figure 2D) and the average yield per country was used for the calculations. The yield data and details for the simulated locations are provided in the Supplemental Information (see Figure S1 and Table S4).

In order to estimate the financial losses due to potential yield losses from soiling, the incentives from power purchase agreements in 2018 were determined for each country; the data is provided in Table S1. For 2023, average electricity prices of $0.03 \in /kWh$ and $0.05 \in /kWh$ were assumed for PV and all countries and for CSP, respectively.

From the collected datasets, the optimum number of cleaning cycles per year, *cyc*, and the corresponding total costs were calculated by cost optimization as follows for each of the top 22 countries (PV) and global CSP. The average number of days between cleanings, *n*, was determined as

$$n = \frac{365}{cyc}.$$
 (Equation 1)

The soiling rate *SR* is defined as an increase of soiling loss per day. This means that for a soiling rate of 0.5 %/day, the soiling loss on the first day will be 0.5 %, on the second day it will be 1%, and on the third day 1.5 %, respectively. In this study, the soiling rate was assumed to be constant between cleaning events, which is typically the case for desert environments. Accordingly, the total, cumulative soiling loss factor between cleaning cycles S_{loss} can be calculated by

Joule

$$S_{loss} = \sum_{k=1}^{n} k \times SR = SR \frac{n^2 + n}{2},$$

(Equation 2)

CellPress

with the index k accounting for all days without cleaning, see also Figure S2 in the supplemental material. Equation 2 assumes a linear soiling derate independently of the value of the soiling loss, up to a maximum loss of 100%. Some authors have been suggesting the use of an exponential function that asymptotically tends to the maximum loss of 100%. ¹¹⁶ However, in this work, linear soiling profile modeling has been preferred, as it directly employs the soiling rate metric, which is widely available in the literature and often reported to match experimental results (see also Table S2).^{17,22,127} From the soiling loss, the annual yield loss Y_{loss} can be determined by multiplication with the installed capacity *C*, the specific annual yield Y_{spec} , and the total number of cleaning cycles per year:

$$Y_{loss} = C \times Y_{spec} \times S_{loss} \times cyc = 365 \ C \times Y_{spec} \times SR \times \frac{n+1}{2}.$$
 (Equation 3)

The solar power generation and supply to the grid is generally rewarded by incentives *I*, as commonly reflected by feed-in tariffs or bid prices, in units of \in /kWh. By multiplication of the lost annual yield with the assumed local incentives, the annual financial loss *F*_{loss} due to soiling of a system can be estimated:

$$F_{loss} = Y_{loss} \times l.$$
 (Equation 4)

On the other hand, the annual cleaning costs are determined by

$$U = u \times C \times \frac{1}{A} \times cyc = u \times C \times \frac{1}{A} \times \frac{365}{n}.$$
 (Equation 5)

u is the cleaning cost per cleaning in \in/m^2 , and A is the module/mirror area efficiency. For PV, module characteristics of 300 W_p and an area of 1.64 m² were assumed, yielding A = 0.183 kW_p/m². For CSP, exemplary values of the plant Noor Ouarzazate III were taken (150 MW, 7400 heliostats with an area of 178.5 m² each), resulting in A = 0.114 kW/m².

The total soiling-related costs *T* is the sum of cleaning costs and financial losses due to reduced energy yield.

$$T = F_{loss} + U.$$
 (Equation 6)

Accordingly, the optimized number of cleaning cycles was calculated by determination of the minimum of the total costs T'(n) = 0, which yields

$$cyc_{opt} = \frac{365}{n_{opt}} = 365\sqrt{\frac{Y_{spec} \times SR \times I \times A}{2u}}.$$
 (Equation 7)

It should be noted that here, the specific yield Y_{spec} needs to be converted to a daily value (annual yield divided by 365). Similar approaches to calculate the optimum cleaning number also resulted in a dependence on the square root of the lost incentives divided by twice the cleaning costs.^{123,125}

As described above, a minimum and maximum optimum number of cleaning cycles was determined for minimum and maximum utility-scale plant cleaning costs and used for calculation of the financial losses for each of the top 22 countries (PV). The global soiling loss was calculated as sum from the top 22 countries:

$$\frac{\sum_{i=1}^{22} Y_{loss,i}(n_{opt,i})}{\sum_{i=1}^{22} C_i Y_{spec,i}}.$$
 (Equation 8)

Accordingly, also the global soiling costs were calculated as sum of top 22 countries

Joule

CellPress



(Equation 9)

Tables with detailed data and references are provided in the Supplemental Information. As Figure 2 demonstrates, the available data, such as soiling rates, are often limited and can vary considerably within a country. This also increases the uncertainty of the rough estimates for the global impact of soiling.

Calculation of the Potential Cost Range for Soiling Mitigation Technologies

The estimated financial losses for each country in the previous section were used to determine the potentially feasible costs range for soiling mitigation technologies assuming specific reductions of soiling rates (see Table 1). For this, the soiling rate in Equation 7 was adapted to the reduced soiling rate $SR_{mitigate}$. The country-specific optimum numbers of cleaning cycles were recalculated and used for determination of the adapted total soiling-related costs $T_{mitigate}$ (see Equation 6). From this, the difference between the total costs for non-mitigated (only cleaning) and mitigated soiling was calculated for each country and divided by the capacity-related area, yielding the potential annual cost savings of soiling mitigation per m² $CS_{mitigate}$.

$$CS_{mitigate,i} = T_i - T_{mitigate,i.}$$
 (Equation 10)

The maximum allowed technology investment costs V_{max} , so that a NPV $\ge 0 \in$ is achieved after a 10-year payback period and a discount rate of 5%, were calculated for each country *i* according to the minimum and maximum cleaning costs by:

$$V_{max,i} = \sum_{l=0}^{9} \frac{CS_{mitigate,i}}{(1+l)^{l}} \approx CS_{mitigate,i} \times 8.11$$
 (Equation 11)

A payback period of 15 years is typical for financing PV plants in moderate climates by bank lenders.¹²⁸ However, for soiling, especially desert environments become relevant, and no reliable data on long-term durability of mitigation technologies is available yet. Accordingly, 10 years were chosen, corresponding to the typical product warranty of PV modules. Discount rates for PV have been reported to be typically in the range of 4%–9% (depending on the country).¹¹³ The average values of V_{max} as displayed in Table 1 were determined as the (non-weighted) mean of all $V_{max,i}$, and the global minimum and maximum values were also provided.

In summary, the calculations in this study indicate the cost range for which investments into soiling mitigation technologies might become profitably compared to standard cleaning approaches. Opportunity investments, such as adding PV capacity to an existing installation, are not considered in this analysis. However, against the background of ultra-low module and system prices, such investments could become reasonable to even replace the cleaning itself, at least in low-soiling environments (see Example S1).

Model Validation

The model results largely build on reported soiling rates and cleaning costs (see Tables S1 and S2). Model validation by correlation with further field data is challenging, because only rare data is available, and there is a large uncertainty because soiling rates and cleaning costs vary considerably already within one country. However, the first attempt of validation can be made by comparing the calculated optimum number of cleaning cycles with typical numbers reported from the field. Some data could be derived from literature and interviews

Joule

CellPress



Figure 5. Sensitivity Analysis of Selected Parameters Influencing the Estimates for Allowed Mitigation Costs

(A) Soiling rate reduction.

(B) Incentives for power generation and supply to the grid.

(C) PV module peak capacity.

(D) Discount rate.

(E) Payback time for calculation of NPV.

for China,¹²⁴ India,¹¹⁴ Germany, and Saudi Arabia¹²⁹ and is plotted as blue lines in Figure 2E. As stated above, the data vary significantly. However, it can be concluded that the model estimates match the expected numbers for different regions quite well.

A second approach for validation is a comparison between the calculated allowed costs for soiling mitigation of 80%–100% (2.5–7.9 \in /m², see Table 1) and the costs for automated cleaning robots (2.4–8.2 \in /m² which match very well ^{49,114} see Table 2). Automated cleaning robots are increasingly gaining relevance in high-soiling areas, ⁵² which is also suggested by the data obtained within this study and demonstrates that the heuristic approach used has the potential to reflect the actual soiling economics.

However, in order to provide a better overview of factors influencing the outcomes, a sensitivity analysis has been performed for soiling rate reductions (Figure 5A), incentives (Figure 5B), PV module peak capacity (Figure 5C), discount rates (Figure 5D), and payback time period (Figure 5E). Only one parameter was changed during each analysis, and the standard parameters used are indicated by red lines in Figure 5. The graphs show the average costs as well as absolute minimum and maximum as derived for minimum and maximum cleaning cost estimates for the different regions (see Equation 8). A more in-depth analysis for selected countries is also provided in Figure S3.

From Figure 5, it can be concluded that the cost estimates are mainly determined by the assumed soiling rate reduction of the respective technology and the incentives for power supply to the grid, followed by the assumed payback period of the initial investment. PV module peak capacity and discount rate have only a minor impact on the final results.

SUPPLEMENTAL INFORMATION

Supplemental Information can be found online at https://doi.org/10.1016/j.joule. 2019.08.019.

Joule

CellPress

ACKNOWLEDGMENTS

This research was funded in part by the Federal Ministry of Education and Research of Germany (BMBF) in the project WÜSTENMODUL (project number 03FH014IX4) and in part by the federal state of Sachsen-Anhalt in the EFRE project "PVFoil" (IB Sachsen-Anhalt, FuE 102/18). L.M. was funded through the European Union's Horizon 2020 research and innovation programme under the NoSoilPV project (Marie Skłodowska-Curie grant agreement no. 793120). F.W. was funded through the European Union's Horizon 2020 research and innovation programme under the SOLWARIS project (grant agreement no. 792103). The authors would like to thank industry partners for provision of photographs and permission to use, including Wenzel Präger Photovoltaik Reinigung (Figures 2B and 2E), solarsol Solarreinigung (Figure 3C), SRS Nord (Figure 2D), Solarpflege.de (Figure 2F), Mohammad Ba'ra (Figure 3A), Sunbrush GmbH (Figure 3B), Staudinger GmbH/Helios (Figure 3C), and NOMADD Desert Solar Solutions (Figure 3D).

AUTHOR CONTRIBUTIONS

Conceptualization, K.I.; Methodology, K.I.; Validation, K.I., D.D., and L.M.; Formal Analysis, K.I. and K.L.; Investigation, K.I., K.L., L.M., B.W.F., D.D., H.H., and V.N.; Visualization K.I.; Writing – Original Draft, K.I., L.M., B.W.F., H.H., and V.N.; Writing – Review & Editing, K.I., L.M., B.W.F., C.H., F.W., V.N., and R.G.; Funding Acquisition, J.B., K.I., and C.H.; Resources, C.H., R.G., and J.B.; Supervision, C.H., R.G., and J.B.

REFERENCES

- Ilse, K.K., Figgis, B.W., Naumann, V., Hagendorf, C., and Bagdahn, J. (2018). Fundamentals of soiling processes on photovoltaic modules. Renew. Sustain. Energy Rev. 98, 239–254.
- Sarver, T., Al-Qaraghuli, A., and Kazmerski, L.L. (2013). A comprehensive review of the impact of dust on the use of solar energy: history, investigations, results, literature, and mitigation approaches. Renew. Sustain. Energy Rev. 22, 698–733.
- Costa, S.C.S., Diniz, A.S.A.C., and Kazmerski, L.L. (2017/2018). Solar energy dust and soiling R&D progress. Literature review update for 2016. Renew. Sustain. Energy Rev. 82, 2504– 2536.
- Costa, S.C.S., Diniz, A.S.A.C., and Kazmerski, L.L. (2016). Dust and soiling issues and impacts relating to solar energy systems. Literature review update for 2012–2015. Renew. Sustain. Energy Rev. 63, 33–61.
- Micheli, L., Deceglie, M.G., and Muller, M. (2019). Mapping photovoltaic soiling using spatial interpolation techniques. IEEE J. Photovoltaics 9, 272–277.
- Micheli, L., and Muller, M. (2017). An investigation of the key parameters for predicting PV soiling losses. Prog. Photovolt: Res. Appl. 25, 291–307.
- Micheli, L., Deceglie, M.G., and Muller, M. (2018). Predicting photovoltaic soiling losses using environmental parameters. An update. Prog. Photovolt Res. Appl. 8, 547.
- Bergin, M.H., Ghoroi, C., Dixit, D., Schauer, J.J., and Shindell, D.T. (2017). Large reductions in solar energy production due to

dust and particulate air pollution. Environ. Sci. Technol. Lett. 4, 339–344.

- You, S., Lim, Y.J., Dai, Y., and Wang, C.-H. (2018). On the temporal modelling of solar photovoltaic soiling. Energy and economic impacts in seven cities. Appl. Energy 228, 1136–1146.
- Javed, W., Guo, B., and Figgis, B. (2017). Modeling of photovoltaic soiling loss as a function of environmental variables. Sol. Energy 157, 397–407.
- Coello, M., and Boyle, L. (2019). Simple model for predicting time series soiling of photovoltaic panels. IEEE J. Photovoltaics 9, 1382–1387.
- Martin-Sanchez, P.M., Gebhardt, C., Toepel, J., Barry, J., Munzke, N., Günster, J., and Gorbushina, A.A. (2018). Monitoring microbial soiling in photovoltaic systems. A qPCR-based approach. Int. Biodeterior. Biodegrad 129, 13–22.
- Einhorn, A., Micheli, L., Miller, D.C., Simpson, L.J., Moutinho, H.R., To, B., Lanaghan, C.L., Muller, M.T., Toth, S., John, J.J., et al. (2019). Evaluation of soiling and potential mitigation approaches on photovoltaic glass. IEEE J. Photovoltaics 9, 233–239.
- Shirakawa, M.A., Zilles, R., Mocelin, A., Gaylarde, C.C., Gorbushina, A., Heidrich, G., Giudice, M.C., Del Negro, G.M.B., and John, V.M. (2015). Microbial colonization affects the efficiency of photovoltaic panels in a tropical environment. J. Environ. Manage 157, 160–167.
- Conceição, R., Silva, H., Mirão, J., and Collares-Pereira, M. (2018). Organic soiling.

The role of pollen in PV module performance degradation. Energies 11, 294.

- Piedra, P., and Moosmüller, H. (2017). Optical losses of photovoltaic cells due to aerosol deposition. Role of particle refractive index and size. Sol. Energy 155, 637–646.
- Ilse, K.K., Figgis, B.W., Werner, M., Naumann, V., Hagendorf, C., Pöllmann, H., and Bagdahn, J. (2018). Comprehensive analysis of soiling and cementation processes on PV modules in Qatar. Sol. Energy Mater. Sol. Cells 186, 309–323.
- Wüllner, J., Steiner, M., Wiesenfarth, M., and Bett, A.W. (2018). Operation & maintenance – the key for reliable performance in a CPV power plant. AIP Conf. Proc. 2012, 020011.
- International Energy Agency. IEA. Renewables (2018). Analysis and Forecasts to 2023 (OECD Publishing).
- IEA PVPS: a snapshot of global PV markets and trend reports. 2019. http://www.iea-pvps. org/fileadmin/dam/public/report/statistics/ IEA-PVPS_T1_35_Snapshot2019-Report.pdf.
- Pelland, S., Pawar, P., Veeramani, A., Gustafson, W., and Etringer, L.L.A. Testing global models of photovoltaic soiling ratios against field test data worldwide. In IEEE 7th World Conference on Photovoltaic Energy Conversion (WCPEC), pp. 3442–3446.
- 22. Kimber, A., Mitchell, L., Nogradi, S., and Wenger, H. (2006). The effect of soiling on large grid-connected photovoltaic systems in California and the Southwest region of the United States. In 2006 IEEE 4th World Conference on Photovoltaic Energy Conference (IEEE), pp. 2391–2395.

Joule

- Merrouni, A.A., Wolfertstetter, F., Mezrhab, A., Wilbert, S., and Pitz-Paal, R. (2015). Investigation of soiling effect on different solar mirror materials under Moroccan climate. Energy Procedia 69, 1948–1957.
- Figgis, B., Guo, B., Javed, W., Ahzi, S., and Rémond, Y. (2018). Dominant environmental parameters for dust deposition and resuspension in desert climates. Aerosol Sci. Technol 52, 788–798.
- Goossens, D., and van Kerschaever, E. (1999). Aeolian dust deposition on photovoltaic solar cells: the effects of wind velocity and airborne dust concentration on cell performance. Sol. Energy 66, 277–289.
- Figgis, B., Ennaoui, A., Ahzi, S., and Rémond, Y. (2017). Review of PV soiling particle mechanics in desert environments. Renew. Sustain. Energy Rev. 76, 872–881.
- Ilse, K.K., Figgis, B.W., Khan, M.Z., Naumann, V., and Hagendorf, C. (2019). Dew as a detrimental influencing factor for soiling of PV modules. IEEE J Photovolt, 287–290.
- Ilse, K.K., Rabanal, J., Schonleber, L., Khan, M.Z., Naumann, V., Hagendorf, C., and Bagdahn, J. (2018). Comparing indoor and outdoor soiling experiments for different glass coatings and microstructural analysis of particle caking processes. IEEE J. Photovoltaics 8, 203–209.
- Ferretti, N., Ilse, K., Sönmez, A., Hagendorf, C., and Berghold, J. (2016). Investigation on the impact of module cleaning on the antireflection coating. In 32nd European Photovoltaic Solar Energy Conference and Exhibition, pp. 1697–1700.
- Toth, S., Muller, M., Miller, D.C., Moutinho, H., To, B., Micheli, L., Linger, J., Engtrakul, C., Einhorn, A., and Simpson, L. (2018). Soiling and cleaning. Initial observations from 5-year photovoltaic glass coating durability study. Sol. Energy Mater. Sol. Cells 185, 375–384.
- Koehl, M., and Hoffmann, S. (2016). Impact of rain and soiling on potential induced degradation. Prog. Photovolt: Res. Appl. 24, 1304–1309.
- Hacke, P., Burton, P., Hendrickson, A., Spataru, S., Glick, S., and Terwilliger, K. Effects of photovoltaic module soiling on glass surface resistance and potentialinduced degradation. In IEEE 42nd Photovoltaics Special Conference, New Orleans, LA, USA, pp. 1–4.
- Schmela, M., Beauvais, A., Chevillard, N., Paredes, M.G., Heisz, M., and Rossi, R. Global Market Outlook.
- Jäger-Waldau, A. PV Status Report 2017. EUR 28817 EN; 10.2760/452611 (Publications Office of the European Union).
- Jäger-Waldau, A. (2018). Snapshot of photovoltaics – February 2018. EPJ Photovolt 9, 6.
- Apostoleris, H., Sgouridis, S., Stefancich, M., and Chiesa, M. (2018). Evaluating the factors that led to low-priced solar electricity projects in the Middle East. Nat. Energy 3, 1109–1114.
- Labordena, M., Neubauer, D., Folini, D., Patt, A., and Lilliestam, J. (2018). Blue skies over

China: the effect of pollution-control on solar power generation and revenues. PLoS One 13, e0207028.

- Boys, B.L., Martin, R.V., van Donkelaar, A., MacDonell, R.J., Hsu, N.C., Cooper, M.J., Yantosca, R.M., Lu, Z., Streets, D.G., Zhang, Q., et al. (2014). Fifteen-year global time series of satellite-derived fine particulate matter. Environ. Sci. Technol 48, 11109– 11118.
- Yang, X., Jiang, L., Zhao, W., Xiong, Q., Zhao, W., and Yan, X. (2018). Comparison of ground-based PM2.5 and PM10 concentrations in China, India, and the U.S. Int. J. Environ. Res. Public Health 15.
- Butt, E.W., Turnock, S.T., Rigby, R., Reddington, C.L., Yoshioka, M., Johnson, J.S., Regayre, L.A., Pringle, K.J., Mann, G.W., and Spracklen, D.V. (2017). Global and regional trends in particulate air pollution and attributable health burden over the past 50 years. Environ. Res. Lett. 12, 104017.
- Weagle, C.L., Snider, G., Li, C., van Donkelaar, A., Philip, S., Bissonnette, P., Burke, J., Jackson, J., Latimer, R., Stone, E., et al. (2018). Global sources of fine particulate matter: interpretation of PM2.5 chemical composition observed by SPARTAN using a global chemical transport model. Environ. Sci. Technol 52, 11670–11681.
- Berg, A., Findell, K., Lintner, B., Giannini, A., Seneviratne, S.I., van den Hurk, B., Lorenz, R., Pitman, A., Hagemann, S., Meier, A., et al. (2016). Land–atmosphere feedbacks amplify aridity increase over land under global warming. Nat. Clim. Change 6, 869–874.
- Dai, A. (2013). Increasing drought under global warming in observations and models. Nat. Clim. Change 3, 52–58.
- Mondal, S., Mondal, A.K., Sharma, A., Devalla, V., Rana, S., Kumar, S., and Pandey, J.K. (2018). An overview of cleaning and prevention processes for enhancing efficiency of solarphotovoltaic panels. Curr. Sci. 6, 1065– 1077.
- 45. Bouaddi, S., Fernández-García, A., Sansom, C., Sarasua, J., Wolfertstetter, F., Bouzekri, H., Sutter, F., and Azpitarte, I. (2018). A review of conventional and innovative- sustainable methods for cleaning reflectors in concentrating solar power plants. Sustainability 10, 3937.
- Jamil, W.J., Abdul Rahman, H., Shaari, S., and Salam, Z. (2017). Performance degradation of photovoltaic power system. Review on mitigation methods. Renew. Sustain. Energy Rev. 67, 876–891.
- Sayyah, A., Horenstein, M.N., and Mazumder, M.K. (2014). Energy yield loss caused by dust deposition on photovoltaic panels. Sol. Energy 107, 576–604.
- Syafiq, A., Pandey, A.K., Adzman, N.N., and Rahim, N.A. (2018). Advances in approaches and methods for self-cleaning of solar photovoltaic panels. Sol. Energy 162, 597–619.
- Ferretti, N. (2018). White paper PV module cleaning. Market overview and basics (PI Photovolatik-Institut Berlin AG). http://www. pi-berlin.com/images/pdf/publication/White

%20Paper%20-%20PV%20Module% 20Cleaning%20-%20Market%20Overview% 20and%20Basics.pdf.

- Mesbahi, M. (2018). White paper soiling: the science & solutions. https://www.solarplaza. com/channels/asset-management/11893/ white-paper-soiling-science-and-solutions/.
- Wolfertstetter, F., Wilbert, S., Dersch, J., Dieckmann, S., Pitz-Paal, R., and Ghennioui, A. (2018). Integration of soiling-rate measurements and cleaning strategies in yield analysis of parabolic trough plants. J. Sol. Energy Eng 140, 41008.
- 52. Gallagher, B. (2018). Rise of the machines: solar module-washing robots. In Wood Mackenzie, GTM Report. https://www. woodmac.com/our-expertise/focus/Power-Renewables/rise-of-the-machines-solarmodule-washing-robots/.
- Figgis, B., Nouviaire, A., Wubulikasimu, Y., Javed, W., Guo, B., Ait-Mokhtar, A., Belarbi, R., Ahzi, S., Rémond, Y., and Ennaoui, A. (2018). Investigation of factors affecting condensation on soiled PV modules. Sol. Energy 159, 488–500.
- 54. Ilse, K.K., Khan, M.Z., Voicu, N., Naumann, V., and Hagendorf, C. (2019). Advanced performance testing of anti-soiling coatings. Part I: laboratory test setup and experimental results. Sol. Energy Mater. Sol. Cells 202, 110048.
- Ilse, K.K., Khan, M.Z., Lange, K., Voicu, N., Naumann, V., and Hagendorf, C. (2019). Advanced performance testing of anti-soiling coatings. Part II: particle-size dependent analysis and determination of adhesion forces. Sol. Energy Mater. Sol. Cells 202, 110049.
- Nayshevsky, I., Xu, Q., Barahman, G., and Lyons, A. (2017). Anti-reflective and antisoiling properties of KleanBoost TM, a superhydrophobic nano-textured coating for solar glass. In IEEE 44th Photovoltaics Spec. Conf., Washington DC.
- Wilke, K.L., Preston, D.J., Lu, Z., and Wang, E.N. (2018). Toward condensation-resistant omniphobic surfaces. ACS Nano 12, 11013– 11021.
- Isbilir, K., Lisco, F., Womack, G., Abbas, A., and Walls, J.M. (2018). Testing of an antisoiling coating for PV module cover glass. In 2018 IEEE 7th World Conference on Photovoltaic Energy Conversion (WCPEC).
- Alkandary, A., Al-Asfour, A.T., and Alzubi, F.G. (2018). Comparative assessment of antisoiling nanocoated photovoltaic modules in an arid desert environment. In 35th European Photovoltaic Solar Energy Conference and Exhibition.
- Brito, P.P., Diniz, A.S.A.C., and Kazmerski, L.L. (2019). Materials design and discovery: potential for application to soiling mitigation in photovoltaic systems. Sol. Energy 183, 791–804.
- Abrams, Z.R., Gonsalves, P., Brophy, B., and Posbic, J. (2014). Field and Lab Verification of Hydrophobic Anti-Reflective and Anti-Soiling Coatings on Photovoltaic Glass. In 29th European Photovoltaic Solar Energy Conference and Exhibition, pp. 2759–2764.



Joule

- 62. Bahattab, M.A., Alhomoudi, I.A., Alhussaini, M.I., Mirza, M., Hegmann, J., Glaubitt, W., and Löbmann, P. (2016). Anti-soiling surfaces for PV applications prepared by sol-gel processing. Comparison of laboratory testing and outdoor exposure. Sol. Energy Mater. Sol. Cells 157, 422–428.
- Brophy, B., Abrams, Z.R., Gonsalves, P., and Christy, K. (2015). Field performance and persistence of anti-soiling coatings on photovoltaic glass. In 31st European Photovoltaic Solar Energy Conference and Exhibition, Hamburg (Germany).
- Brown, K., Narum, T., and Jing, N. (2012). Soiling test methods and their use in predicting performance of photovoltaic modules in soiling environments. In Photovoltaic Specialists Conference (PVSC) 38th IEEE, 2012, pp. 1881–1885.
- 65. Chabas, A., Alfaro, S., Lombardo, T., Verney-Carron, A., Da Silva, E., Triquet, S., Cachier, H., and Leroy, E. (2014). Long term exposure of self-cleaning and reference glass in an urban environment: A comparative assessment. Build. Environ 79, 57–65.
- Figgis, B.W., and Brophy, B. (2015). PV coatings and particle adhesion forces. In Conference Proceedings PV-Days Halle, Germany 2015.
- Grammatico, M.A., and Littmann, B.W. (2016). Quantifying the anti-soiling benefits of antireflective coatings on first solar cadmium telluride PV modules 43th Photovoltaics Spec. conference, Portland, OR (IEEE), pp. 1697– 1701.
- Hirohata, T., Ota, Y., and Nishioka, K. (2015). Anti-soiling coating based on silica for Fresnel lens of concentrator photovoltaics. Jpn. J. Appl. Phys. 54, 8.
- Jang, G.G., Smith, D.B., Polizos, G., Collins, L., Keum, J.K., and Lee, D.F. (2019). Transparent superhydrophilic and superhydrophobic nanoparticle textured coatings: comparative study of anti-soiling performance. Nanoscale Adv 1, 1249–1260.
- Piliougine, M., Cañete, C., Moreno, R., Carretero, J., Hirose, J., Ogawa, S., and Sidrach-de-Cardona, M. (2013). Comparative analysis of energy produced by photovoltaic modules with anti-soiling coated surface in arid climates. Appl. Energy 112, 626–634.
- Sakhuja, M., Son, J., Yang, H., Bhatia, C.S., and Danner, A.J. (2014). Outdoor performance and durability testing of antireflecting and self-cleaning glass for photovoltaic applications. Sol. Energy 110, 231–238.
- Dross, F., Voicu, N., Carcouet, C., Tummers, P., Li, Y., and Schoot, H. (2018). Novel antisoiling coatings to enhance PV plant output and financial performance International PV Soiling Workshop; Denver. https:// pvqataskforceqarating.pbworks.com/w/file/ 130606323/2.6%20DSM%20AS%20Coatings %20Dross.pdf.
- Ahrens, P. (2018). CSD nano coating development International PV Soiling Workshop; Denver. https://pvqatask forcegarating.pbworks.com/w/page/

130798518/2018%20International%20Soiling %20Workshop.

- Conceição, R., Silva, H.G., Fialho, L., Lopes, F.M., and Collares-Pereira, M. (2019). PV system design with the effect of soiling on the optimum tilt angle. Renew. Energy 133, 787–796.
- Figgis, B., Guo, B., Javed, W., Ilse, K., Ahzi, S., and Remond, Y. (2017). Time-of-day and Exposure Influences on PV Soiling 5th International Renewable and Sustainable Energy Conference (IRSEC'17), Tangier, Morocco (IEEE), pp. 1–4.
- Roth, E.P., and Pettit, R.B. (1980). The effect of soiling on solar mirrors and techniques used to maintain high reflectivity. In Solar Materials Science (Elsevier), pp. 199–227.
- Figgis, B.W., and Ilse, K.K. (2019). Soiling reduction by modified PV tracker. In 36th European Photovoltaic Solar Energy Conference and Exhibition (EU-PVSEC), Marseille, France.
- Bhaduri, S., Chattopadhyay, S., Zachriah, S., Solanki, C.S., and Kottantharayil, A. (2016). Evaluation of increase in the energy yield of PV modules by inverting the panels during the non-sunshine hours. In 26th Int. Photovolt. In Sci. Eng. Conf..
- Bhaduri, S., and Kottantharayil, A. (2018). Mitigation of soiling by vertical mounting of bifacial modules. IEEE J. Photovoltaics 9, 1–5.
- Kolb, G.J., Jones, S.A., Donnelly, M.W., Gorman, D., Thomas, R., Davenport, R., and Lumia, R. Heliostat Cost Reduction Study. SAND2007–3293, Sandia National Laboratories, ed.
- Bkayrat, R. (2013) Lessons Learnt with PV Power Plants in the US Desert. First Solar; VP Business Development Saudi Arabia.
- 82. Wolfertstetter, F.A. (2016). Dissertation (RWTH Aachen).
- Ahmad, N., Khandakar, A., El-Tayeb, A., Benhmed, K., Iqbal, A., and Touati, F. (2018). Novel design for thermal management of PV cells in harsh environmental conditions. Energies 11, 3231.
- Preet, S. (2018). Water and phase change material based photovoltaic thermal management systems. A review. Renew. Sustain. Energy Rev. 82, 791–807.
- Guo, B., Figgis, B., and Javed, W. (2019). Measurement of electrodynamic dust shield efficiency in field conditions. J. Electrostat 97, 26–30.
- Kawamoto, H., and Shibata, T. (2015). Electrostatic cleaning system for removal of sand from solar panels. J. Electrostat 73, 65–70.
- Faes, A., Petri, D., Champliaud, J., Geissbühler, J., Badel, N., Levrat, J., et al. (2019). Field test and electrode optimization of electrodynamic cleaning systems for solar panels. Prog. Photovolt. Res. Appl. https:// doi.org/10.1002/pip.3176.
- Kawamoto, H. (2019). Electrostatic cleaning equipment for dust removal from soiled solar panels. J. Electrostat 98, 11–16.

- Sayyah, A., Eriksen, R.S., Horenstein, M.N., and Mazumder, M.K. (2016). Performance analysis of electrodynamic screens based on residual particle size distribution. IEEE J Photovolt, 1–9.
- Lu, F., Guo, S., Walsh, T.M., and Aberle, A.G. (2013). Improved PV module performance under partial shading conditions. Energy Procedia 33, 248–255.
- Hanifi, H., Schneider, J., and Bagdahn, J. (2015). Reduced shading effect on half-cell modules – measurement and simulation. In 31st European Photovoltaic Solar Energy Conference and Exhibition, pp. 2529–2533.
- Qian, J., Clement, C.E., Ernst, M., Khoo, Y.S., Thomson, A., and Blakers, A. (2019). Analysis of hotspots in half cell modules undetected by current test standards. IEEE J. Photovolt, 1–7.
- Mittag, M. (2018). The impact of half cells on module power and costs. Webinar PV Mag. Freiburg. https://www.researchgate.net/ publication/329512345_The_impact_ of_half_cells_on_module_power_and_costs.
- 94. Wolfertstetter, F., Wilbert, S., Terhag, F., Hanrieder, N., Fernandez-García, A., Sansom, C., King, P., Zarzalejo, L., and Ghennioui, A. (2019). Modelling the soiling rate: dependencies on meteorological parameters. In SOLARPACES 2018: International Conference on Concentrating Solar Power and Chemical Energy Systems (AIP Publishing).
- Conceição, R., Silva, H.G., and Collares-Pereira, M. (2018). CSP mirror soiling characterization and modeling. Sol. Energy Mater. Sol. Cells 185, 233–239.
- Picotti, G., Borghesani, P., Cholette, M.E., and Manzolini, G. (2018). Soiling of solar collectors – modelling approaches for airborne dust and its interactions with surfaces. Renew. Sustain. Energy Rev. 81, 2343–2357.
- Gostein, M., Passow, K., Deceglie, M.G., Micheli, L., and Stueve, B. (2018). Local variability in PV soiling rate Proceedings of the World Conference on Photovoltaic Energy Conversion (WCPEC-7), Hawai.
- Etyemezian, V., Nikolich, G., and Gillies, J.A. (2017). Mean flow through utility scale solar facilities and preliminary insights on dust impacts. J. Wind Eng. Ind. Aerodyn 162, 45–56.
- Moghimi, M.A., and Ahmadi, G. (2018). Wind barriers optimization for minimizing collector mirror soiling in a parabolic trough collector plant. Appl. Energy 225, 413–423.
- Sansom, C., King, P., Fernández-García, A., Almond, H., Kayani, T., and Boujjat, H. (2018) The Design of Dust Barriers to Reduce Collector Mirror Soiling in CSP Plants, pp. 30017.
- 101. IEC 61724-1, Edition 1.0, 2017-03: Photovoltaic system performance – Part 1: Monitoring.
- 102. Gostein, M., Faullin, S., Miller, K., Schneider, J., and Stueve, B. (2018). Mars™ soiling sensor. In 35th European Photovoltaic Solar Energy Conference and Exhibition, pp. 1523–1527.

CellPress

Joule

- Korevaar, M., Mes, J., Alami Merrouni, A., Bergmans, T., Nepal, P., and van Mechelen, X. (2018). Unique soiling detection system for PV modules. In 35th European Photovoltaic Solar Energy Conference and Exhibition.
- 104. Muller, M., Morse, J., Almonacid, F., Fernández, E.F., and Micheli, L. (2018). Design and indoor validation of "DUSST": a novel low-maintenance soiling station. In 35th European Photovoltaic Solar Energy Conference and Exhibition, pp. 1991–1995.
- 105. Curtis, T., Tatapudi, S., and Tamizhmani, G. (2018). Design and operation of a Waterless PV Soiling Monitoring Station. In IEEE 7th World Conference on Photovoltaic Energy Conversion (WCPEC), pp. 3407–3412.
- 106. Wolfertstetter, F., Pottler, K., Geuder, N., Affolter, R., Merrouni, A.A., Mezrhab, A., and Pitz-Paal, R. (2014). Monitoring of mirror and sensor soiling with TraCS for improved quality of ground based irradiance measurements. Energy Procedia 49, 2422–2432.
- 107. Fernández-García, A., Sutter, F., Martínez-Arcos, L., Sansom, C., Wolfertstetter, F., and Delord, C. (2017). Equipment and methods for measuring reflectance of concentrating solar reflector materials. Sol. Energy Mater. Sol. Cells 167, 28–52.
- Fernández-Reche, J. (2006). Reflectance measurement in solar tower heliostats fields. Sol. Energy 80, 779–786.
- 109. Zhu, G., Kearney, D., and Mehos, M. (2014). On characterization and measurement of average solar field mirror reflectance in utilityscale concentrating solar power plants. Sol. Energy 99, 185–202.
- 110. 5–10 June 2016 Qasem, H., Mnatsakanyan, A., and Banda, P. (2016). Assessing dust on PV modules using image processing techniques. In IEEE 43rd Photovoltaic Specialists Conference (PVSC) 2016 (IEEE Publications), pp. 2066–2070.
- 111. Yap, W.K., Galet, R., and Yeo, K.C. (2015). Quantitative analysis of dust and soiling on solar PV panels in the tropics utilizing imageprocessing methods. In Asia-Pacific Solar Research Conference.

- 112. Zefri, Y., ElKettani, A., Sebari, I., and Lamallam, S.A. (2018). Thermal infrared and visual inspection of photovoltaic installations by UAV photogrammetry—application case: morocco. Drones 2, 41.
- 113. Freyman, T., and Tran, T. (2019). Renewable energy discount rate survey results. In A Grant Thornton and Clean Energy Pipeline Initiative, G. Thornton, ed.. https://www.grantthornton. co.uk/globalassets/1.-member-firms/unitedkingdom/pdf/documents/renewable-energydiscount-rate-survey-results-2018.pdf.
- 114. Choori, G.P. (2018). Robotic module cleaning Indian context International PV Soiling Workshop; Denver. https://pvqataskfor ceqarating.pbworks.com/w/page/130798518/ 2018%20International%20Soiling% 20Workshop.
- 115. Tzikas, C., Cappa, M., van den Donker, M.N., Sommeling, P.M., Verbong, G.P.J., and Folkerts, W. (2018). Business cases for anti-soiling coatings in the Netherlands. In 35th European Photovoltaic Solar Energy Conference and Exhibition, pp. 1519–1522.
- 116. Jones, R.K., Baras, A., Saeeri, A.A., Al Qahtani, A., Al Amoudi, A.O., Al Shaya, Y., Alodan, M., and Al-Hsaien, S.A. (2016). Optimized cleaning cost and schedule based on observed soiling conditions for photovoltaic plants in central Saudi Arabia. IEEE J. Photovolt, 1–9.
- Lorenz, T., Klimm, E., and Weiss, K.-A. (2014). Soiling and anti-soiling coatings on surfaces of solar thermal systems – featuring an economic feasibility analysis. Energy Procedia 48, 749–756.
- Stridh, B. (2012). Evaluation of economical benefit of cleaning of soiling and snow in PV plants at three European locations 38th IEEE Photovoltaic Specialists Conference (PVSC), pp. 1448–1451.
- 119. Cordero, R.R., Damiani, A., Laroze, D., MacDonell, S., Jorquera, J., Sepúlveda, E., Feron, S., Llanillo, P., Labbe, F., Carrasco, J., et al. (2018). Effects of soiling on photovoltaic (PV) modules in the Atacama Desert. Sci. Rep 8, 13943.

- Tanesab, J., Parlevliet, D., Whale, J., and Urmee, T. (2018). Energy and economic losses caused by dust on residential photovoltaic (PV) systems deployed in different climate areas. Renew. Energy 120, 401–412.
- 121. Alqatari, S., Alfaris, A., and de Weck, O.L. (2015). Cost and performance comparative model of dust mitigation technologies for solar PV in Saudi Arabia. J. Environ. Sci.
- 122. Fuentealba, E., Ferrada, P., Araya, F., Marzo, A., Parrado, C., and Portillo, C. (2015). Photovoltaic performance and LCoE comparison at the coastal zone of the Atacama Desert, Chile. Energy Convers. Manag 95, 181–186.
- 123. Young, D. (2014). Wash or not to wash? Framework for making an informed decision. https://www.google.co.in/search? q=Wash+or+Not+to+Wash?+Framework+ for+Making+an+Informed+Decision&cad=h.
- 124. Zhao, B., Zhang, S., Cao, S., and Zhao, Q. (2019). Cleaning cycle optimization and cost evaluation of module dust for photovoltaic power plants in China. Clean Techn. Environ. Policy 36, 2615.
- Abu-Naser, M. (2017). Solar panels cleaning frequency for maximum financial profit. OJEE 06, 80–86.
- 126. Al-Kouz, W., Al-Dahidi, S., Hammad, B., and Al-Abed, M. (2019). Modeling and analysis framework for investigating the impact of dust and temperature on PV systems' performance and optimum cleaning frequency. Appl. Sci. 9, 1397.
- Deceglie, M.G., Micheli, L., and Muller, M. (2018). Quantifying soiling loss directly From PV yield. IEEE J. Photovoltaics 8, 547–551.
- Holz, F. (2018). PV energy systems: economic considerations and risks from a Finance Perspective. PV Days 2018 (Deutsche Bank).
- 129. Hermann, W. (2019). Energy yield of PV power plants – approaches for the determination of yield losses due to dust soiling in desert climates. In Dust Workshop "the Effect of Soiling on Solar Energy", Intersolar Europe, Munich Edicion. https://cost-indust.eu/ events/indust-events.

