

# Efficient Transition Towards Renewable Energy

German Aerospace Center (DLR)  
Institute of Technical Thermodynamics  
Department of System Analysis & Technology Assessment,  
Stuttgart

Carsten Hoyer-Klick, Denis Hess, Franz Trieb

European Commission  
DG Energy  
Brussels 08.01.2014

Knowledge for Tomorrow



# Criteria for Sustainable Electricity Supply:

## 1. Affordability

- Low cost
- Low subsidies
- Low structural effort

## 2. Security

- Diversification of supply
- Power on demand and redundancy
- Sustainable energy resources
- Available technology

## 3. Environmental compatibility

- Low pollution, climate protection
- Low risks for health and nature
- Low land use and structural impacts

## 4. Social compatibility

- Fair access to energy
- Balance of dependencies and interdependencies
- Flexibility during transition



## Portfolio of Energy Sources for Electricity:

- ✓ Coal, Lignite
  - ✓ Oil, Gas
  - ✓ Nuclear Fission, Fusion
  - ✓ Concentrating Solar Power (CSP)
  - ✓ Geothermal Power (Hot Dry Rock)
  - ✓ Biomass
  - ✓ Hydropower
  - ✓ Wind Power
  - ✓ Photovoltaic
  - ✓ Wave / Tidal
- ideally stored primary energy
- storable primary energy
- fluctuating primary energy



## Important Frame Condition:

The available firm capacity must be larger than peak load

$$\sum P_{\text{installed}} \cdot CC \geq S \cdot P_{\text{load, max}}$$

$P_{\text{installed}}$

installed capacity

CC

capacity credit of each technology

$P_{\text{load, max}}$


peak load

S

security margin (e.g. 1.25 for 25% reserve capacity)



## Principle of a Concentrating Solar Thermal Power Plant



- concentrated, easily storable solar thermal energy as fuel saver
- spinning reserve
- firm capacity, power on demand
- combined generation of process heat for cooling, industry, desalination, etc.




## Why CSP imports from North Africa?

Higher availability than in EU → flexible renewable power

CSP with large solar field and storage (SM4) at three sites:

### NA advantages:

- more sunny days
- lower latitude
- ➔ lower seasonal variation of electricity yield



# The Conventional Alternating Current (AC) Electricity Grid

1. **AC grid** capacity (NTC) in NA between 0.5 to 1.0 GW (Germany 8.5 GW)
  2. If the AC grid grows proportional to power demand, it will achieve German standards by 2050 only in Egypt (8 GW NTC), but not in the rest of NA
  3. Long-distance losses in AC grid are high (10-15%/1000 km)
  4. No traceability of electricity sources in the AC grid
- ➔ Balancing of power supply and demand between neighbors to increase redundancy and plant utilization: **yes**
  - ➔ Long-distance transport of flexible solar power on demand: **no**
  - ➔ **AC grid is not suitable for long-distance exports from NA to EU, but for balancing among direct NA-EU neighbors**



## Point-to-Point HVDC Links

1. **HVDC links** (100 GW) used world-wide to bring flexible renewable power from A to B
  2. A 15% contribution to EU demand in 2050 will require 100 GW NTC
  3. Long-distance losses in HVDC links are low (3-5%/1000 km)
  4. Full traceability of electricity sources in a HVDC link
- ➔ Balancing of power supply and demand between (oversea) neighbors to increase redundancy and plant utilization: **yes**
  - ➔ Long-distance transport of flexible solar power on demand: **yes**
  - ➔ **HVDC is suitable for long-distance exports from NA to EU, and can also be used for balancing among NA-EU neighbors over the Mediterranean**




# Flexible Solar Power Imports from a European Point of View





# Identification of 33 corridors – REACCESS (2008)




# ... incl. Solar Electricity Imports from North Africa

Color indicates year of commissioning

- 2020 (Purple dashed line)
- 2030 (Blue dashed line)
- 2040 (Green dotted line)
- 2050 (Yellow dashed line)

Existing AC grid (Grey dashed line)

5000 (Arrow) Net import capacity [MW]




## Energy Data Analysis Tool *EnDAT*

Hourly profiles of RE generation, electricity and heat demand

### RE potentials

Installable capacities, power plant model, hourly power output, cost and full load hour potentials (PV, CSP, Wind, Hydro, Waves)



### Electricity demand



### Heat demand



### Technology Diffusion



Hourly RE generation profile

Hourly load profile

Hourly load profile

Hourly load profile

RE-Generation  
PV, CSP, Wind, Geothermal, Waves, Hydro, Biomass

Conventional Generation  
Nuclear, Lignite, CCGT, Gas

Flexible CHP  
Heat storage, Peak boiler, Electric boiler, Solar share

Heat Generation  
CHP, Heat Pumps, Gas & Biomass, Solar

Demand Response  
Industry & private sector

E-Mobility  
**BEV/EREV:** charge strategies, V2G. Battery capacity hourly resolved  
**FCEV:** flexible on-site H<sub>2</sub>-generation



Storage  
Pumped hydro, Compressed air, Hydrogen

## Energy System Optimization Model *OptiMo*

Temporally and spatially resolved cost-minimized energy supply

### Transmission


**AC-Grid Transmission**  
Current transfer capacities  
**DC-Grid-Transmission**  
HVDC inter-country level  
**DC-CSP-Transmission**  
HVDC CSP plants in Africa



Result: Strategies for Generation, Transmission and Balancing




# Electricity Demand Europe (ENERGEO 2012)







Power generation 2010


- CSP import HVDC
- Coal
- CCGT
- Nuclear
- Biomass
- Geothermal
- CSP
- Hydro Runoff
- Wave
- Wind Offshore
- Wind Onshore
- Photovoltaic
- Net import AC



AC-transmission  
7.1 ▶ Transferred power [TWh/a]  
39% Mean annual line utilisation








# Effect on the EU Electricity Grid


Grid load is reduced!

No additional storage needed!

Consistent and compatible country scenarios!



# Flexible Solar Power Imports from a German Point of View




# Paradigm change in the load profile


in the year 2012 in BW

until the year 2050

summer




Power [MW]




100% RE

winter





Power [MW]



# A 90% RES-E scenario for Germany without CSP imports: 375 GW + 40 GW NTC + 40 GW Storage

Energy source	Installed Capacity MW	Annual electricity yield TWh/a	average utilization h/a
<b>Variable / renewable</b>	235500	551.3	
Photovoltaics	100000	98.9	989
Wind Onshore	70000	156.4	2235
Wind Offshore	60000	257.7	4295
River Runoff	5500	38.2	6951
<b>Flexible / renewable</b>	8000	37.9	
Biomass, Waste	4000	22.1	5515
Wood, Biogas	4000	15.9	3964
Geothermal		0.0	0
Import Hydro		0.0	0
Import CSP		0.0	0
<b>Fossil / Nuclear</b>	90000	56.4	
Gas Turbines	90000	56.4	627
Coal Plants	0	0.0	0
Combined Cycle	0	0.0	0
Nuclear Plants	0	0.0	0
Lignite Plants	0	0.0	0
<b>Storage and net transfer</b>	80000	48.7	
Pump Storage, CAES	20000	15.7	785
Hydrogen Storage	20000	13.8	688
H2-Storage Capacity (days)	1		
Net Transfer Capacity (NTC)	40000	19.3	482
<b>Total power park</b>	<b>373500</b>	<b>579</b>	<b>1551</b>





low average utilization



# A 90% RES-E scenario for Germany with CSP imports:

**225 GW + 8 GW NTC + 20 GW HVDC + 8 GW Storage**

Energy source	Installed Capacity MW	Annual electricity yield TWh/a	average utilization h/a
<b>Variable / renewable</b>	117500	288.1	
Photovoltaics	45000	44.5	989
Wind Onshore	40000	89.4	2235
Wind Offshore	27000	116.0	4295
River Runoff	5500	38.2	6951
<b>Flexible / renewable</b>	35000	220.2	
Biomass, Waste	4000	30.0	7502
Wood, Biogas	7000	49.8	7112
Geothermal	4000	30.2	7547
Import Hydro	4000	25.8	6462
Import CSP	16000	84.3	5271
<b>Fossil / Nuclear</b>	65000	54.4	
Gas Turbines	65000	54.4	837
Coal Plants	0	0.0	0
Combined Cycle	0	0.0	0
Nuclear Plants	0	0.0	0
Lignite Plants	0	0.0	0
<b>Storage and net transfer</b>	16000	3.1	
Pump Storage, CAES	7500	1.9	255
Hydrogen Storage	0	0.0	0
H2-Storage Capacity (days)	0		
Net Transfer Capacity (NTC)	8500	1.1	135
<b>Total power park</b>	<b>225000</b>	<b>561</b>	<b>2494</b>



higher average utilization



## **CSP imports from NA to Germany via HVDC links will lead to:**


1. 150 GW less power plants for the German “Energiewende”
2. 5 times less grid capacity (no significant expansion)
3. 5 times less power storage (no significant expansion)
4. 90% RES-E can be achieved much faster and with much less effort
5. Allows every European country to follow a similar strategy without creating external costs by RES-E surplus and gaps to be balanced by neighbors

### **Alternative:**

Surplus (??) from Moroccan wind power and PV (??) exported to Europe through a “Supergrid” in Andalusia (??)



# Model of a first CSP-HVDC link between Morocco and Germany



# Discussion partners of the study – Transmission of dispatchable solar energy from North Africa to Central Europe

## industry



TRÄNSNET BW



Rte


Réseau de transport d'électricité



masen  
Moroccan Agency  
for Solar Energy



## research



Universität  
Stuttgart



## ministries



Bundesministerium  
für Wirtschaft  
und Technologie



Ministère de l'Énergie, des Mines,  
de l'Eau et de l'Environnement  
Département de l'Environnement



Ciemat  
Centro de Investigaciones  
Energéticas, Medioambientales  
y Tecnológicas




Ministerium für Umwelt, Klima und Energiewirtschaft  
Baden-Württemberg

## cooperative society



# Transmission of dispatchable solar energy: CSP-HVDC link



DNI: Direct Normal Irradiance  
 CSP: Concentrating Solar Power  
 HVDC: High Voltage Direct Current



# First model of a CSP-HVDC link, cost and land requirements

## MOR-E-F-D

HVDC 2600 km  
 1.7 GW / 1.5 GW<sub>net</sub>  
 1,9 – 5,1 billion €  
 150 km<sup>2</sup>

CSP 2.2 GW  
 CSP 12 -18 billion €  
 150 km<sup>2</sup>

## MOR-E-F-D


HVDC 2300 km  
 1.7 GW / 1.5 GW<sub>net</sub>  
 3,7 – 4,9 billion €  
 75km<sup>2</sup>

CSP 2.2 GW  
 CSP 12 -18 billion €  
 150 km<sup>2</sup>


-> 9.32 TWh/a  
 16-23 billion € (real 2010)  
 feasible until 2024

O&M:  
 4-5 €Cent/kWh

LCOE:  
 12-15 €Cent/kWh




# Total investment cost of the four CSP-HVDC alternatives




# Adequate permanent payment for the required land

## Overhead line




## Underground cable




unit

$$\left[ \frac{\text{€Cent}}{\text{TWh} \cdot \text{m}^2 \cdot \text{y}} \right]$$




cheaper overhead line and more expensive underground cable can reach through this compensation payment **cost neutrality** within their lifetime!



free choice of technology is made possible -> increased acceptance




# Annual income for the concerned nations, their municipalities and landowners (riparians) – each time with 4 routes




Today only the blue value is paid for the construction of transmission lines in Germany **ONCE!**




# Annual operation cost of the four CSP-HVDC alternatives




# Traffic light model of decision steps




# Time limit for a decision



# How can the investment be paid that low interests incur and thus the capital costs remain low?




# Tariff of the CSP-HVDC site Mis-Eic with underground cable - How can 16 billion € be paid that low interests incur and thus the capital costs remain low?




# How can 16 billion € be paid that low interests incur and thus the capital costs remain low?

Apportionment of the costs on all electricity customers




Savings (black) and additional costs (red) accumulated in 40 years versus dispatchable fossil fuels (coal / gas)



## Investment plan based on a standardised and unified European apportionnement depending on consum of each country

- every member state will profit from learning curve
  - every member state will get the capacity for that the state has paid
  - stabilising the european electricity market with firm, constant cheap and renewable energy
  - european apportionnement will not stress EU industry competition
- > with about **2 €Cent/kWh** on a consumption of 3300 TWh/a all present european nuclear power plants (~125 GW) can be replaced by more flexible and renewable CSP-HVDC sites in the next **20 years**



# Conclusions

- For an electricity system with ~100% RE dispatchable renewable energy is necessary
- Only CSP with a new HVDC point-to-point infrastructure can enable an export of dispatchable renewable energy form North Africa to Europe
- The investment costs are at about 16-23 billion € for CSP and HVDC
- If we decide in 2013/2014 the project could be feasible until 2025
- Due to the compensation costs for the required land area, overhead transmission lines and underground cables can reach cost neutrality
- To avoid high capital costs guarantees (AAA, PPA) and a short capital repayment period are needed



## Current dialogs

- German-Moroccan Energy Partnership (Government Level, BMWi)



Bundesministerium  
für Wirtschaft  
und Technologie

Royaume du Maroc



Ministère de l'Énergie, des Mines,  
de l'Eau et de l'Environnement

Département de l'Environnement

- FP7 Project BETTER (4<sup>th</sup> cooperation mechanism)



- Internal workshops with discussion partners



DLR

Deutsches Zentrum  
für Luft- und Raumfahrt

German Aerospace Center




## Further steps


- preparation of a handbook for public participation
- publication of further scientific studies on the necessity of dispatchable solar electricity imports to Baden-Wuerttemberg on a multilingual website
- questioning of citizens in case studies in exemplary communities
- detailed cost-benefit analysis with risk assessment
- cooperation with ENTSO, TransnetBW, RTE, REE, ONEE in preparation for the inclusion in the "Union List" of a project with common interests (EU Regulation 347/2013)
- support of the necessary application documents and the required measures
- search for suitable project responsible



# Potential information network for a multinational civil project




# International Cooperative Society for Citizen Participation




**green:** in favour  
**red:** refusal  
**white:** not yet decided

# Declaration of intent on state level





*exemplary scientific model*




green: in favour  
red: refusal  
white: not yet decided

# Declaration of intent on regional level




**green:** in favour  
**red:** refusal  
**white:** not yet decided

# Declaration of intent on municipal level




*exemplary scientific model*




green: in favour  
red: refusal  
white: not yet decided

# Declaration of intent on owner level



*exemplary scientific model*



## On the interactive website can also appear:

- Image video about this potential project (animation of the power plant function, need in the energy system of a Central European control area, data and interviews with affected people of the power station, the transmission line and electricity customers)
- All current activities with citizens, in politics, science and economy
- Schedule of citizen participation and overall schedule
- All data in the field of economy, ecology, technology, social and institutional
- Already achieved progress and critique



**Thank you for your attention!**

[carsten.hoyer-klick@dlr.de](mailto:carsten.hoyer-klick@dlr.de)

[denis.hess@dlr.de](mailto:denis.hess@dlr.de)

[franz.trieb@dlr.de](mailto:franz.trieb@dlr.de)



# Appendix

Knowledge for Tomorrow



# Construction in Phases



- Phase I  
Transport of solar power from southern Europe to the central European demand centres
- Bundle of cables which end in the participating countries
- Phase II  
Import of balancing power throughout the year from northern Africa

